

FUNCTIONAL SERVICING & STORMWATER MANAGEMENT REPORT

IN SUPPORT OF RE-ZONING & DRAFT PLAN OF
SUBDIVISION APPLICATIONS

Regent Park Phases 4 and 5
City of Toronto



8395 Jane Street, Suite 100
Vaughan, Ontario L4K 5Y2
Tel: (905) 326-1404
File Number: 20030

Prepared For:
Toronto Community Housing Corp.
&
2747199 Ontario Limited (Tridel)

3	Issued for 3 rd Submission	April 10, 2023
2	Issued for 2 nd Submission	November 30, 2022
1	Issued for 1 st Submission	April 14, 2022
No.	Revision	Date



TABLE OF CONTENTS

LIST OF FIGURES, DRAWINGS, TABLES & APPENDICES	3
1.0 INTRODUCTION	4
1.1 Purpose.....	4
1.2 Background.....	4
1.3 Study Parameters	5
2.0 STORMWATER MANAGEMENT	5
2.1 Existing Conditions	5
2.2 Proposed Conditions.....	6
2.3 Allowable Release Rate	6
2.4 QuAntity Control.....	8
2.5 FOUNDATION DRAINAGE.....	9
2.6 Water Quality	10
2.7 Water Balance	10
2.8 Erosion and Sediment Control	11
3.0 SANITARY SERVICING	11
3.1 Existing Sanitary Servicing.....	11
3.2 Proposed Sanitary Release Rate.....	11
4.0 WATERMAIN SERVICING	13
4.1 Existing Water Servicing	13
4.2 Domestic Demand	13
4.3 Fire Demand	14
4.4 Total Demand	14
5.0 PROPOSED PUBLIC ROADS	15
6.0 CONCLUSIONS	16



LIST OF FIGURES, DRAWINGS, TABLES & APPENDICES

Figures

Figure 1	Site Location Plan
Figure 2	Proposed Concept Plan

Tables

Table 1a	Allowable Release Rate Buildings
Table 1b	Allowable Release Rate Roads
Table 2	Peak Flow and Storage Summary - 100-Year Storm Event
Table 3	Approved vs Proposed Release Rates
Table 4	Sanitary Discharge Summary
Table 5	Domestic Water Demand Summary

Appendices

Appendix A	Storm Servicing
Appendix B	Sanitary Servicing
Appendix C	Water Servicing



1.0 INTRODUCTION

1.1 PURPOSE

Counterpoint engineering has been retained by Toronto Community Housing Corporation (TCHC) and their development partner *2747199 Ontario Limited (Tridel)* to prepare this Functional Servicing & Stormwater Management Report in support of the Rezoning and Draft Plan of Subdivision applications being submitted for the subject lands.

The purpose of this Report is to address conceptually the provision of storm and sanitary sewers, stormwater management, water distribution, and road servicing for the proposed residential development. Additionally, the Report will provide details on stormwater management in response to Toronto's Wet Weather Flow Management Master Plan (WWFMMP) Guidelines.

This Report is also intended to meet the requirements of development approval required under the Planning Act, which in turn satisfies the conditions for the Municipal Class Environment Assessment process for the storm and sanitary sewers, stormwater management, water distribution and road servicing for the subject lands.

1.2 BACKGROUND

The phase 4 & 5 Regent Redevelopment lands are located between Oak Street to the south, Gerrard Street East to the North, River Street to the east and Dreamers Way to the west. The redevelopment block is subdivided by existing TCHC owned Sackville Street & Sumach Street that run between Oak Street and Gerrard Street. Although not municipal roads, both streets have existing municipal combined sewers and Watermains. This report is intended to supplement to the original May 2005 FSR prepared by Dillon Consulting. The remaining redevelopment area is approximately 6.45 ha and is made up of three redevelopment blocks with two existing roads (Sackville Street & Sumach Street) that will become Public Roads and two new Public Roads (Street G & Tubman Avenue).

It should be noted that as part of the revitalization of Regent Park new municipal roads with new/revitalize municipal servicing has been installed on Oak Street, Sackville Street, Sumach



Street and Tubman Avenue between River Street to the east, Parliament Street to the west, Dundas Street East to the south and Oak Street to the north. Additionally, Dreamers Way between Oak Street and Gerrard Street just east of Parliament Street. As mentioned above, the roads and their associated sewers and watermains are active and are in the process of final maintenance and assumption.

The proposed redevelopment for the subject site will consist of 4 development blocks with 5 midrise buildings of a maximum of 12 stories and 7 high rise buildings ranging from 18 to 39 stories. Each of the three development blocks will have a common element underground that is shared and accessed by the buildings above. Ownership of the mid and high rise buildings will be split between TCHC and Market units. Refer to the proposed Building Heights & Setbacks plan prepared by Karakusevic Carson Architects.

1.3 STUDY PARAMETERS

The background documents listed below have been considered in the functional grading and servicing design for the proposed site and preparation of this Report:

- Concept Master Plan prepared by Karakusevic Carson Architects;
- City of Toronto Design Criteria for Sewers and Watermains, 2021;
- City of Toronto Wet Weather Flow Management Guidelines, November 2006;
- Toronto Sewer Atlas, 2010
- Fire Underwriters Survey, 1999

2.0 STORMWATER MANAGEMENT

2.1 EXISTING CONDITIONS

The site is currently serviced by the existing municipal infrastructure within the adjacent roads to the blocks. As storm sewer were only introduced to this area in the past few years because



of the earlier Regent Park Phases, storm flows from the existing buildings and surfaces drain to the existing combined sewers. Additionally, the current buildings have no on-site quality or quantity controls.

Under the original redevelopment condition, the 6.45 ha site is identified to have three main drainage areas. Block 2 to Sackville Street plus half of Block 5 drains to the Dundas Street Storm Trunk via the Storm sewer on Sackville. The remainder of Block 5 to Sumach Street drains to the Dundas Street Storm Trunk via the Sumach Storm sewer and Blocks 8 to 10 drain to the Dundas Storm Trunk via storm sewers on Tubman Avenue. Refer to the **Storm Drainage Plan SD-1** in appendix 'A' for the existing proposed drainage patterns and areas.

2.2 PROPOSED CONDITIONS

Each of the Four redevelopment blocks will be developed with a common element underground encompassing the majority of the blocks. As such the allowable release has been calculated assuming one Stormwater Management Tank per Building underground per ownership element except for part of Block 3 that will have no underground. The storage for these buildings (3F and 3G) will be provided by an underground storage system to be connected to the Oak Street Storm sewer. The eastern 0.37 ha of block 5 on plan SD-1 that was previously designed with the drainage split between the two outlets has been redirected to solely drain to the Sumach Storm sewer. As this is additional flow to the Sumach outlet, the capacity of the Oak and Sumach Storm sewers were reviewed. The review determined that the addition of this small area (0.37 ha @ 0.50) would not impact the existing drainage system. The stormwater tanks for the majority of the buildings will be located near or along the Oak Street frontage and connections will be made to the storm sewers within the adjacent ROW.

2.3 ALLOWABLE RELEASE RATE

The sites imperviousness under existing conditions is higher than 50%. Under Wet Weather Guidelines the maximum value of C (Runoff Coefficient) used in calculating the pre-development peak runoff rate is limited to 0.50 for the 2-year storm event. As the existing site has greater than 50% imperviousness this rule applies.



In Table 1a below the allowable release rates for the development blocks have been broken down based on the building ownership (TCHC/Market). Table 1b speaks to the allowable release rates for the three public roads. The allowable release from buildings and roads have been based on the above criteria and has been displayed in the table below.

$$Q_A = C \times A \times i \times N \text{ (L/s)}$$

Table 1a - Allowable Release Rate Buildings

Variables	Building 1A	Building 2B & C	Building 3D & E	Building 3F & G	Building 3H & I	Building 4J & K	Building 5L & M
A - Site Area (ha)	0.55	0.83	0.81	0.60	0.95	0.94	0.96
T_c (min)	10	10	10	10	10	10	10
C - Runoff Coefficient	0.50	0.50	0.50	0.50	.5	0.50	0.50
i - Intensity	88.19	88.19	88.19	88.19	88.19	88.19	88.19
N - Constant	2.778	2.778	2.778	2.778	2.778	2.778	2.778
Q - Release Rate (L/s)	67.4	101.7	99.2	73.5	116.4	115.1	117.6
	To Sackville 169.1		To Sumach 289.1			To River 232.7	

Table 1b - Allowable Release Rate Roads

Variables	Street G	Sackville Street	Sumach Street	Tubman Avenue
A - Site Area (ha)	0.18	0.22	0.23	0.18
T_c (min)	10	10	10	10
C - Runoff Coefficient	0.50	0.50	0.50	0.50
i - Intensity	88.19	88.19	88.19	88.19
N - Constant	2.778	2.778	2.778	2.778
Q - Release Rate (L/s)	22.0	26.9	28.2	22.0
Total Flows To	Sackville St. 218.0		Sumach 317.3	Tubman 254.8



2.4 QUANTITY CONTROL

The allowable post development release rate to the redevelopment Blocks will be **218.0, 317.3 & 254.8 L/s** as individually calculated in Section 2.3.

Quantity control will be provided on-site via underground storage tanks/systems within the P1 Levels of the common element undergrounds for each TCHC/Market Buildings. The storage for auxiliary buildings (3F and 3G) will be provided by an underground storage system to be connected to the Oak Street Storm sewer. To ensure that the 100-year post development peak flows from the sites are attenuated to their 2-year allowable release rate. An onsite storage system and orifice control device will be required on each storm service connection. Refer to **Appendix A** for detailed calculations.

Table 2 – Peak Flow and Storage Summary - 100-Year Storm Event

Area ID	Area (ha)	Runoff Coefficient	t_c (min)	Storage Available (m ³)	Storage Required (m ³)	100-Year Release Rate (L/s)	Description	Size (mm)
Outlet to Sackville								-
Building 1A	0.55	0.85	10		155	67.4	TBD	
Street G ROW	0.180	0.85	10		51	22.0	TBD	
Building 2B&C	0.83	0.85	10		234	101.7	TBD	
Sackville ROW	0.22	0.85	10		62	26.9	TBD	
	1.78	0.85	10		501	218.0		Outlet Allowable 218.0 l/s
Outlet to Sumach								
Building 3D&E	0.810	0.85	10		228	99.2	TBD	
Building 3F&G	0.600	0.85	10		169	73.5	TBD	
Building 3H&I	0.950	0.85	10		267	116.4	TBD	
Sumach ROW	0.230	0.85	10		65	28.2	TBD	
	2.59	0.85	10		501	317.3		Outlet Allowable 317.3 l/s
Outlet to River								
Building 4J&K	0.940	0.85	10		265	115.1	TBD	
Tubman ROW	0.180	0.85	10		51	22.0	TBD	
Building 5L&M	0.960	0.85	10		270	117.6	TBD	
	2.08	0.85	10		585	254.8		Outlet Allowable 254.8 l/s
Total	6.450			0	1587	790.1		

1. Refer to **Appendix A** for modified rational calculations.



In emergency and/or extreme weather conditions the at grade access lid to the underground storage tank located adjacent to Oak Street will allow water to discharge overland to the municipal street. The access lid is to be as per OPSD 401.010 – Type B – Open Cover.

The design of all internal piping within the building must provide adequate capacity for full capture and conveyance of all flows generated by storms up to and including the 100-year rainfall event. All design and associated calculations for the internal storm system, including the design of the internal inlet structures, piping and mechanical appurtenances is to be completed by the Mechanical Engineer.

Table 3 – Approved vs Proposed Release Rates

Area ID	Area (ha)	Runoff Coefficient	t_c (min)	Intensity (i)	Approved Release Rate (L/s)	Proposed Release Rate (L/s)
Outlet to Sackville	2.130	0.58	10	88.19	301.1	218.0
Outlet to Sumach	2.230	0.61	10	88.19	333.9	317.3
Outlet to Tubman	2.080	0.54	10	88.19	273.4	254.8
	6.440					

Based on the Table 3 above the approved allowable release from the development blocks and roads are greater than the proposed release rates. As such, there will be capacity within the existing Storm sewer system to service the proposed development.

2.5 FOUNDATION DRAINAGE

As per the City of Toronto's Sewer-Use Bylaw, sewer connections for foundation drainage are not permitted. Groundwater flow have not been included in the storm or sanitary flow calculations. All building will be built with watertight foundations to eliminate the need for long term groundwater discharge.

Short-term discharge for each block will be determined based on the block specific needs. If required, further details will be provided as part of the Site Plan Approval process. It is expected that the any short-term discharge will drain to the sanitary sewer system.



2.6 WATER QUALITY

The Wet Weather Flow Management Guidelines stipulate that 80% removal of TSS is required on an average annual loading basis from all runoff leaving the proposed development.

Each block at detailed design will be evaluated based on land-use to determine the initial TSS removal credit and the amount of remaining TSS removal required. The site shall also capture the 5mm storm event, which will capture an average of 50% of annual rainfall, therefore removing this volume out of the runoff discharged, and providing a 50% TSS removal average. A stormwater treatment unit shall be provided for each block connection, which provides an additional TSS removal. The treatment units are proposed to be upstream of each of the proposed storm connections from the sites to the receiving municipal sewers in the right-of-way. These combined efforts will achieve the 80% TSS removal target.

2.7 WATER BALANCE

The Wet Weather Flow Guidelines indicate that the minimum on-site runoff retention requires the proponent to retain all runoff from a small design rainfall event for impervious areas – typically 5mm (In Toronto, storms with 24 hour volumes of 5mm or less contribute about 50% of the total average annual rainfall volume). Water balance efforts such as the use of green roofs, landscaped areas, and water reuse cisterns will be provided to achieve the required water balance objectives.

A water reuse cistern is suggested as a low-impact development strategy for each of the blocks/block connections that are sized to provide storage for the 5mm storm. These water balance efforts, along with the approximate provided landscape areas will provide adequate 5mm water balance for the entire site. Further details will be provided during detailed design.



2.8 EROSION AND SEDIMENT CONTROL

During construction, erosion and sediment control will be implemented on site. This will be achieved through methods such as installation of a silt fence around the perimeter of the site, placement of mud mats at site access points to municipal roadways and the use of sediment control barriers at catchbasins located in proximity to the site. Further site specific erosion and sediment control measures will be considered during detailed design which is to be completed after draft plan approval is granted.

3.0 SANITARY SERVICING

3.1 EXISTING SANITARY SERVICING

As part of the previous three development phases of the Regent Park Revitalization the existing combined sewers servicing the future phases 4 and 5 were replaced with separated Storm and Sanitary sewer that were installed on Oak Street. Under the proposed condition the Sanitary flows for the new phases will be conveyed to either the Sackville, Sumach or River Street outlet to the HLI. Capacity for the future development blocks have been created by eliminating the Storm flows from the existing combined sewer system. This will be discussed in detail in a later section of this report. For previous subdivision sewer works please refer to the Drainage Plans attached to the report in **Appendix B**.

3.2 PROPOSED SANITARY RELEASE RATE

The proposed developments will be serviced by municipal connections to the existing sanitary sewers on Oak Street, or new public sanitary sewer and/or to the Combined sewers on Sackville or Sumach. As discussed above the Sanitary capacity for the development has been created by directing the storm flows from the sites away from the combined sewer system and to the dedicated storm sewers constructed as part of the previous phases of work and proposed.



Using the City of Toronto Sanitary Design criteria, the equivalent population for the proposed buildings were determined and Sanitary flows calculated and summarized based on the collecting sewer branch that discharges to the HLI. Details on each building within the development can be found in **Appendix B**.

The equivalent population for the proposed development was calculated using the non-residential floor space, the residential unit breakdown, the city of Toronto person per unit and office space guidelines to be approximately **7272 persons**. Using a per capita flow of **240 l/s** for residential areas and **250 l/s** for commercial areas, the resulting peak sanitary flow for the proposed development has been calculated to be approximately **68.76 l/s** including an infiltration allowance of 0.26 L/s/ha. Refer to **Appendix B** for detailed calculations.

Table 4 – Sanitary Discharge Summary

Drainage Outlet	Existing Sanitary (L/S)	Offset Storm Flows (L/S)	Proposed Sanitary (L/s)	Net Change (L/s)	Approved Sanitary Discharge Phase III (L/s)
Sackville					
Block 1	13.2	253.5			
Part of Block 2	4.29	83.19			
Total	17.49	336.69	28.76	307.93	20.18
Sumach					
Block 2	8.27	159.2	11.12	148.08	13.08
River					
Block 3 & 4	12.07	254.8	28.88	225.92	21.63

*Approved discharge based on plan SS-1

Based on the offset of the storm flows there is capacity within the existing sewer system for the proposed redevelopment. Based on this methodology the site will be in compliance with MECP Procedure F-5-5.

However, as the Proposed Sanitary flows are greater than the previously approved flows for the Sackville and River outlets a review of the local Oak Street sanitary sewer capacity was undertaken. The results of the Oak Street capacity review have been included in **Appendix B**. Based on the calculations both the Sackville Outlet and the River Outlet have free flow capacity



after the additional sanitary flows were added. As such, we expect no capacity issues within the Sanitary drainage system and the existing infrastructure can support the Phase IV & V revitalization as proposed.

4.0 WATERMAIN SERVICING

4.1 EXISTING WATER SERVICING

The existing site as well as the surrounding municipal roads currently have a watermain network servicing the site. The existing site buildings are currently serviced by connections to the existing municipal watermains. The available surrounding watermains are as follows:

- An existing 200mm watermain along Oak Street
- An existing 200mm watermain along Dreamers Way
- An existing 150mm watermain along Gerrard Street East
- An existing 150mm watermain along River Street
- An existing 300mm watermain along Sumach Street
- An existing 150mm watermain along Sackville Street

4.2 DOMESTIC DEMAND

The expected domestic water usage rate for the development was calculated based on site stats and usage rate of **190 litres/capita/day** for apartments and condominiums based on the City's required per capita demand. Maximum day and peak hour factors were based on the City of Toronto Design Criteria for residential and commercial land use and calculated by separately defined blocks.

The domestic demands for each development block within the site have been calculated and summarized in **Table 5** below. Refer to **Appendix C** for water demand calculations.



Table 5 – Domestic Water Demand Summary

Building	Population	Maximum Day Flow (l/min)	Peak Hour Flow (l/min)	Minimum Hour Flow (l/min)
1A	863	146	270	96
2B	499	84	157	55
2C	779	134	257	86
3D	421	71	129	47
3E	532	91	172	59
3F	153	26	50	17
3G	16	2	5	2
3H	482	81	149	53
3I	528	90	170	59
4J	502	85	158	56
4K	766	131	252	85
5L	849	145	274	94
5M	923	157	299	102
TOTAL	7270	1233	2305	806

4.3 FIRE DEMAND

Fire flow demand was estimated using the Fire Underwriters Survey. The development blocks primarily consist of residential apartment buildings with retail/office areas. Each apartment building was assumed to be of fire-resistive construction and sprinklered. This means that the floor area shall be estimated using the largest floor area plus 25% of the next two adjoining floors. Fire flow was calculated for the observed critical/largest building of the site. It was determined that the most critical fire flow was identified at Building 4L, which had a resulting fire flow of **9,000 L/min**. Refer to **Appendix C** for the fire flow demand calculations for the critical Blocks on-site.

4.4 TOTAL DEMAND

The total demand is the greater of Maximum Day + Fire Flow or the Peak Hour Demand. Based on Fire Flow requirements, Maximum Day + Fire Flow governs the water demand for the proposed development. Therefore, the development shall provide the required flow and pressures during max day demand, which is summarized for each block above in **Table 5**, plus



fire flow. Based on the calculations, it is anticipated that Building 5L will govern the overall maximum day plus fire flow demand requirement of **9,145 L/min** (9,000 L/min + 145 L/min).

The City of Toronto Design Criteria sets out watermain pressure requirements and can be summarized as follows:

1. Maximum Pressure = under normal conditions the maximum static pressure shall not exceed 690 kPa (100 psi).
2. The minimum pressure under any non-fire demand scenario will not be less than 275 kPa (40 psi)
3. Under conditions of simultaneous maximum day and fire flow demands, the pressure shall not drop below 140 kPa (20 psi) at any point in the water system.

The capacity of the surrounding watermain infrastructure was confirmed around the proposed development by a series of flow tests conducted by Lozzi Aqua Check on November 17, 2021. Copies of the flow tests have been included in **Appendix C** with the for detailed calculations of the water demand. Based on observations, there are no anticipated issues with the water servicing for the development. As part of Site Plan Approval, a FSR will be provided for each block to address the final design of the building and the fire demand impact of it.

5.0 PROPOSED PUBLIC ROADS

The redevelopment site is well serviced by a network of existing public roads that will provide access to the development blocks. As a result, two new public roads are proposed (Street G & Tubman Avenue). The surface treatment of existing Sackville Street and Sumach Street will be modified to provide a better pedestrian experience and these existing roads will be made Municipal streets as well. A proposed cross section for Tubman & Street G has been included in **Appendix C**.



6.0 CONCLUSIONS

This FSR/SWM report presents a site servicing strategy for the proposed development that addresses the requirements of the applicable regulatory agencies and provides the basis for detailed servicing and Stormwater management design. Based on the review of the existing municipal servicing, the proposed redevelopment can be accommodated with no adverse downstream impact or any external upgrades.

We trust this report sufficiently addresses all aspects of the site servicing.


Sincerely,
Counterpoint Engineering Inc.

James Few
905-326-3087
jfew@counterpointeng.com




Rasheed Serrao, P.Eng.
416-629-7805
rserrao@counterpointeng.com

BERRARD STREET EAST



KEY PLAN

N.T.S.



CLIENT
Toronto Community Housing Corporation (TCHC) and 2747199 Ontario Limited (Deltra Inc.)

THIS DRAWING IS BASED ON DIMENSIONAL SURVEY INFORMATION PROVIDED BY OTHERS AND REPRESENTS THE ARCHITECT'S BEST CURRENT UNDERSTANDING OF EXISTING CONDITIONS. THE ARCHITECT CANNOT ACCEPT RESPONSIBILITY FOR THE ACCURACY OF THIS SURVEY INFORMATION.
 ALL DIMENSIONS ARE SHOWN IN METRIC. DO NOT SCALE FROM THIS DRAWING.
 THIS DRAWING REMAINS THE COPYRIGHT OF KARAKUSEVIC CARSON ARCHITECTS AND MAY NOT BE USED WITHOUT THEIR EXPRESSED WRITTEN CONSENT.
 THESE DRAWINGS ARE NOT FOR CONSTRUCTION

- NOTES
- Plot Boundary
 - Phases 4&5 Property Line
 - City of Toronto Owned Lands
 - Potential Retention
 - Potential Mechanical Penthouse

All heights measured from established grade to penthouse, excluding mechanical plant and parapets.

Established grade measured above Canadian Geodetic Datum

P04 S3 P3 - Draft for Client Review	03/24/23
P03 S4 P2 - Issued for ZBA	11/29/22
P02 S3 P2 - Draft for Client Review	11/15/22
P01 S4 P1 - Issued for ZBA	04/14/22
P00 S3 P1 - Draft for Client Review	04/01/22

Rev: Status Reason for Issue Date

ARCHITECT OF RECORD
E.R.A. Architects Inc.
 625 Church St
 Suite 600
 Toronto
 Ontario, M4Y 2G1
 info@eraarch.ca | 416 963 4497




DESIGN
Karakusevic Carson Architects
 Studio 501
 37 Cremer St
 Hackney
 London E2 8HD
 mail@karakusevic-carson.com | +44(0)207 566 6300


PROJECT
Regent Park Phases 4 & 5



TITLE
Site Plan

DRAWING NUMBER	577 - KCA - XX - DR - A - 0003	REVISION	P04
STATUS	S3 - Draft for Client Review	STAGE	P3
REVISION DATE	03/24/23	DRAWN BY	H/AJAN
FIRST ISSUED	04/01/22	CHECKED BY	PK/RM
		KCA PROJECT NUMBER	577



DRAFT





CLIENT
Toronto Community Housing Corporation (TCHC) and 2747199 Ontario Limited (Deltra Inc.)

THIS DRAWING IS BASED ON DIMENSIONAL SURVEY INFORMATION PROVIDED BY OTHERS AND REPRESENTS THE ARCHITECT'S BEST CURRENT UNDERSTANDING OF EXISTING CONDITIONS. THE ARCHITECT CANNOT ACCEPT RESPONSIBILITY FOR THE ACCURACY OF THIS SURVEY INFORMATION.
 ALL DIMENSIONS ARE SHOWN IN METRIC. DO NOT SCALE FROM THIS DRAWING.
 THIS DRAWING REMAINS THE COPYRIGHT OF KARAKUSEVIC CARSON ARCHITECTS AND MAY NOT BE USED WITHOUT THEIR EXPRESSED WRITTEN CONSENT.
THESE DRAWINGS ARE NOT FOR CONSTRUCTION

NOTES
 FOR LANDSCAPE DETAILS REFER TO DRAWINGS BY PFS.
 FOR PARKING AND LOADING OPERATION REFER TO DRAWINGS BY BA GROUP.

- Phases 4&5 Property Line
- City of Toronto Owned Lands Right of Way
- 1B
- 1B+
- 2B
- 2B+
- 3B
- 3B+
- 4B
- 5B
- Amenity
- Ancillary
- Civic
- Community
- Lobby
- Retail
- Residential Outdoor Amenity

Bike Parking Schedule - Level G

Plot	Building	Level	Name	Est. No. of Bikes
1	A	Level 0	Bikes - Non Residential	20
1	B	Level 0	Bikes - Short Term	10
2	D	Level 0	Bikes - Short Term	70
2	E	Level 0	Bikes - Short Term	50
2	F	Level 0	Bikes - Non Residential	20
2	H	Level 0	Bikes - Short Term	70
2	I	Level 0	Bikes - Non Residential	150
2	J	Level 0	Bikes - Short Term	50
3	J	Level 0	Bikes - Short Term	70
3	K	Level 0	Bikes - Long Term	50
3	K	Level 0	Bikes - Short Term	50
3	L	Level 0	Bikes - Short Term	70
3	L	Level 0	Bikes - Short Term	70
3	M	Level 0	Bikes - Non Residential	24
3	M	Level 0	Bikes - Long Term	40
Grand total				700

P02 S3 P2 - Draft for Client Review	11/15/22
P01 S4 P1 - Issued for ZBA	04/14/22
P00 S3 P1 - Draft for Client Review	04/01/22


ARCHITECT OF RECORD
E.R.A. Architects Inc.
 625 Church St
 Suite 600
 Toronto
 Ontario, M4Y 2G1
 info@eraarch.ca | 416 963 4497

DESIGN
Karakusevic Carson Architects
 Studio 501
 37 Cremer St
 Hackney
 London E2 8HD
 mail@karakusevic-carson.com | +44(0)207 566 6300

PROJECT
Regent Park Phases 4 & 5

TITLE
Ground Floor Plan

DRAWING NUMBER	REVISION
577 - KCA - XX - 01 - DR - A - 1004	P02
STATUS	STAGE
S3 - Suitable for review and comment	P2
DRAWN BY HA/JAN	SCALE 1 : 1000 @ ARCH D
FIRST ISSUED 04/01/22	CHECKED BY PK/RM
	KCA PROJECT NUMBER 577



DRAFT



Appendix A

Storm Servicing

counterpoint engineering

Project Name: Regent Park Phase 4 & 5
Project Number: 21123

Rainfall Data		
Location:	Toronto	a
Event	100 Year	b
		c

Area ID	Area (ha)	Runoff Coefficient	t_c (min)	Intensity (i)	Approved Release Rate (L/s)
Outlet to Sackville	2.130	0.58	10	88.19	301.1
Outlet to Sumach	2.230	0.61	10	88.19	333.9
Outlet to Tubman	2.080	0.54	10	88.19	273.4
	6.440				

counterpoint engineering

Allowable Release Rate

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Site Area 0.18 ha

Rational Method - Allowable Release Rate - Street G

Event: years

ABC's:	A	<input type="text" value="21.8"/>
	C	<input type="text" value="0.78"/>
Time of Concentration:	t	<input type="text" value="10"/> min
Runoff Coefficient:	C	<input type="text" value="0.5"/>
Site Area	A	<input type="text" value="0.180"/> ha
Intensity $i=A/(T)^c$	i	<input type="text" value="88.19"/> mm/hr
Flow $Q=CiA/360$	Q	<input type="text" value="0.022"/> m ³ /s <input type="text" value="22.0"/> l/s

counterpoint engineering

Allowable Release Rate

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Site Area 0.18 ha

Rational Method - Allowable Release Rate - Street J

Event: years

ABC's:	A	<input type="text" value="21.8"/>
	C	<input type="text" value="0.78"/>
Time of Concentration:	t	<input type="text" value="10"/> min
Runoff Coefficient:	C	<input type="text" value="0.5"/>
Site Area	A	<input type="text" value="0.180"/> ha
Intensity $i=A/(T)^c$	i	<input type="text" value="88.19"/> mm/hr
Flow $Q=CiA/360$	Q	<input type="text" value="0.022"/> m ³ /s <input type="text" value="22.0"/> l/s

counterpoint engineering

Allowable Release Rate

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Site Area 0.22 ha

Rational Method - Allowable Release Rate - Sackville Street

Event: years

ABC's:	A	<input type="text" value="21.8"/>
	C	<input type="text" value="0.78"/>
Time of Concentration:	t	<input type="text" value="10"/> min
Runoff Coefficient:	C	<input type="text" value="0.5"/>
Site Area	A	<input type="text" value="0.220"/> ha
Intensity $i=A/(T)^c$	i	<input type="text" value="88.19"/> mm/hr
Flow $Q=CiA/360$	Q	<input type="text" value="0.027"/> m ³ /s <input type="text" value="26.9"/> l/s

counterpoint engineering

Allowable Release Rate

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Site Area 0.23 ha

Rational Method - Allowable Release Rate - Sumach Street

Event: years

ABC's:	A	<input type="text" value="21.8"/>
	C	<input type="text" value="0.78"/>
Time of Concentration:	t	<input type="text" value="10"/> min
Runoff Coefficient:	C	<input type="text" value="0.5"/>
Site Area	A	<input type="text" value="0.230"/> ha
Intensity $i=A/(T)^c$	i	<input type="text" value="88.19"/> mm/hr
Flow $Q=CiA/360$	Q	<input type="text" value="0.028"/> m ³ /s <input type="text" value="28.2"/> l/s

counterpoint engineering

Allowable Release Rate

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Site Area 0.55 ha

Rational Method - Allowable Release Rate - Bldg 1A

Event: years

ABC's:	A	<input type="text" value="21.8"/>
	C	<input type="text" value="0.78"/>
Time of Concentration:	t	<input type="text" value="10"/> min
Runoff Coefficient:	C	<input type="text" value="0.5"/>
Site Area	A	<input type="text" value="0.550"/> ha
Intensity $i=A/(T)^c$	i	<input type="text" value="88.19"/> mm/hr
Flow $Q=CiA/360$	Q	<input type="text" value="0.067"/> m ³ /s <input type="text" value="67.4"/> l/s

counterpoint engineering

Allowable Release Rate

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Site Area 1.01 ha

Rational Method - Allowable Release Rate - Bldg 1B & C

Event: years

ABC's:	A	<input type="text" value="21.8"/>
	C	<input type="text" value="0.78"/>
Time of Concentration:	t	<input type="text" value="10"/> min
Runoff Coefficient:	C	<input type="text" value="0.5"/>
Site Area	A	<input type="text" value="1.010"/> ha
Intensity $i=A/(T)^c$	i	<input type="text" value="88.19"/> mm/hr
Flow $Q=CiA/360$	Q	<input type="text" value="0.124"/> m ³ /s <input type="text" value="123.7"/> l/s

counterpoint engineering

Allowable Release Rate

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Site Area 0.81 ha

Rational Method - Allowable Release Rate - Bldg 2D & E

Event: years

ABC's:	A	<input type="text" value="21.8"/>
	C	<input type="text" value="0.78"/>
Time of Concentration:	t	<input type="text" value="10"/> min
Runoff Coefficient:	C	<input type="text" value="0.5"/>
Site Area	A	<input type="text" value="0.810"/> ha
Intensity $i=A/(T)^c$	i	<input type="text" value="88.19"/> mm/hr
Flow $Q=CiA/360$	Q	<input type="text" value="0.099"/> m ³ /s
		<input type="text" value="99.2"/> l/s

counterpoint engineering

Allowable Release Rate

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Site Area 0.6 ha

Rational Method - Allowable Release Rate - Bldg 2F & G

Event: years

ABC's:	A	<input type="text" value="21.8"/>
	C	<input type="text" value="0.78"/>
Time of Concentration:	t	<input type="text" value="10"/> min
Runoff Coefficient:	C	<input type="text" value="0.5"/>
Site Area	A	<input type="text" value="0.600"/> ha
Intensity $i=A/(T)^c$	i	<input type="text" value="88.19"/> mm/hr
Flow $Q=CiA/360$	Q	<input type="text" value="0.073"/> m ³ /s
		<input type="text" value="73.5"/> l/s

counterpoint engineering

Allowable Release Rate

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Site Area 0.95 ha

Rational Method - Allowable Release Rate - Bldg 2H & I

Event: years

ABC's:	A	<input type="text" value="21.8"/>
	C	<input type="text" value="0.78"/>
Time of Concentration:	t	<input type="text" value="10"/> min
Runoff Coefficient:	C	<input type="text" value="0.5"/>
Site Area	A	<input type="text" value="0.950"/> ha
Intensity $i=A/(T)^c$	i	<input type="text" value="88.19"/> mm/hr
Flow $Q=CiA/360$	Q	<input type="text" value="0.116"/> m ³ /s <input type="text" value="116.4"/> l/s

counterpoint engineering

Allowable Release Rate

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Site Area 0.94 ha

Rational Method - Allowable Release Rate - Bldg 3 J & K

Event: years

ABC's:	A	<input type="text" value="21.8"/>
	C	<input type="text" value="0.78"/>
Time of Concentration:	t	<input type="text" value="10"/> min
Runoff Coefficient:	C	<input type="text" value="0.5"/>
Site Area	A	<input type="text" value="0.940"/> ha
Intensity $i=A/(T)^c$	i	<input type="text" value="88.19"/> mm/hr
Flow $Q=CiA/360$	Q	<input type="text" value="0.115"/> m ³ /s <input type="text" value="115.1"/> l/s

counterpoint engineering

Allowable Release Rate

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Site Area 0.96 ha

Rational Method - Allowable Release Rate - Bldg 4 L & M

Event: years

ABC's:	A	<input type="text" value="21.8"/>
	C	<input type="text" value="0.78"/>
Time of Concentration:	t	<input type="text" value="10"/> min
Runoff Coefficient:	C	<input type="text" value="0.5"/>
Site Area	A	<input type="text" value="0.960"/> ha
Intensity $i=A/(T)^c$	i	<input type="text" value="88.19"/> mm/hr
Flow $Q=CiA/360$	Q	<input type="text" value="0.118"/> m ³ /s <input type="text" value="117.6"/> l/s

counterpoint engineering

Project Name: Regent Park Phase 4 & 5
 Project Number: 21123

Rainfall Data			
Location:	Toronto	a	59.7
Event	100 Year	b	0
		c	0.8

Area ID	Area (ha)	Runoff Coefficient	t_c (min)	Storage Available (m ³)	Storage Required (m ³)	100-Year Release Rate (L/s)	Description	Size (mm)
Outlet to Sackville								
Building 1A	0.55	0.85	10		155	67.4	TBD	
Street G ROW	0.180	0.85	10		51	22.0	TBD	
Building 1B&C	0.83	0.85	10		234	101.7	TBD	
Sackville ROW	0.22	0.85	10		62	26.9	TBD	
	1.78	0.85	10		501	218.0		Outlet Allowable 218.0 l/s
Outlet to Sumach								
Building 2D&E	0.810	0.85	10		228	99.2	TBD	
Building 2F&G	0.600	0.85	10		169	73.5	TBD	
Building 2H&I	0.950	0.85	10		267	116.4	TBD	
Sumach ROW	0.230	0.85	10		65	28.2	TBD	
	2.59	0.85	10		501	317.3		Outlet Allowable 317.3 l/s
Outlet to River								
Building 3J&K	0.940	0.85	10		265	115.1	TBD	
Tubman ROW	0.180	0.85	10		51	22.0	TBD	
Building 4L&M	0.960	0.85	10		270	117.6	TBD	
	2.08	0.85	10		585	254.8		Outlet Allowable 254.8 l/s
	6.450			0	1588	790.0		

counterpoint engineering

Modified Rational

Area: Building 1A

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Rainfall Data			
Location:	Toronto	a	59.700
Event	100 Year	b	0.000
		c	0.800

Site Data	
Area	0.550 ha
Runoff Coefficient	0.85
AC	0.47
Tc	10
Time Increment	10
Release Rate	67.4 L/s
Storage Required	155 m ³

Time	Rainfall Intensity	Storm Runoff	Runoff Volume	Released Volume	Storage Volume	
(min)	(mm/hr)	(m ³ /s)	(m ³)	(m ³)	(m ³)	
10	250	0.33	195	40	155	*****
20	144	0.19	224	81	143	
30	104	0.14	243	121	122	
40	83	0.11	258	162	96	
50	69	0.09	269	202	67	
60	60	0.08	279	243	37	
70	53	0.07	288	283	5	
80	47	0.06	296	323	-27	
90	43	0.06	303	364	-61	
100	40	0.05	309	404	-95	
110	37	0.05	315	445	-129	
120	34	0.04	321	485	-164	
130	32	0.04	326	525	-199	
140	30	0.04	331	566	-235	
150	29	0.04	335	606	-271	
160	27	0.04	340	647	-307	
170	26	0.03	344	687	-343	
180	25	0.03	348	728	-380	
190	24	0.03	352	768	-416	
200	23	0.03	355	808	-453	
210	22	0.03	359	849	-490	
220	21	0.03	362	889	-527	
230	20	0.03	365	930	-564	

counterpoint engineering

Modified Rational

Area: Building 1B&C

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Rainfall Data			
Location:	Toronto	a	59.700
Event	100 Year	b	0.000
		c	0.800

Site Data	
Area	1.010 ha
Runoff Coefficient	0.85
AC	0.86
Tc	10
Time Increment	10
Release Rate	123.7 L/s
Storage Required	284 m ³

Time	Rainfall Intensity	Storm Runoff	Runoff Volume	Released Volume	Storage Volume	
(min)	(mm/hr)	(m ³ /s)	(m ³)	(m ³)	(m ³)	
10	250	0.60	358	74	284	*****
20	144	0.34	412	148	263	
30	104	0.25	447	223	224	
40	83	0.20	473	297	176	
50	69	0.16	495	371	123	
60	60	0.14	513	445	68	
70	53	0.13	529	520	9	
80	47	0.11	543	594	-50	
90	43	0.10	556	668	-112	
100	40	0.09	568	742	-174	
110	37	0.09	579	816	-237	
120	34	0.08	589	891	-302	
130	32	0.08	599	965	-366	
140	30	0.07	608	1039	-432	
150	29	0.07	616	1113	-497	
160	27	0.07	624	1188	-564	
170	26	0.06	632	1262	-630	
180	25	0.06	639	1336	-697	
190	24	0.06	646	1410	-764	
200	23	0.05	653	1485	-832	
210	22	0.05	659	1559	-900	
220	21	0.05	665	1633	-968	
230	20	0.05	671	1707	-1036	

counterpoint engineering

Modified Rational

Area: Sackville ROW

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Rainfall Data			
Location:	Toronto	a	59.700
Event	100 Year	b	0.000
		c	0.800

Site Data	
Area	0.220 ha
Runoff Coefficient	0.85
AC	0.19
Tc	10
Time Increment	10
Release Rate	26.9 L/s
Storage Required	62 m ³

Time	Rainfall Intensity	Storm Runoff	Runoff Volume	Released Volume	Storage Volume	
(min)	(mm/hr)	(m ³ /s)	(m ³)	(m ³)	(m ³)	
10	250	0.13	78	16	62	*****
20	144	0.07	90	32	57	
30	104	0.05	97	49	49	
40	83	0.04	103	65	38	
50	69	0.04	108	81	27	
60	60	0.03	112	97	15	
70	53	0.03	115	113	2	
80	47	0.02	118	129	-11	
90	43	0.02	121	146	-24	
100	40	0.02	124	162	-38	
110	37	0.02	126	178	-52	
120	34	0.02	128	194	-66	
130	32	0.02	130	210	-80	
140	30	0.02	132	226	-94	
150	29	0.01	134	243	-108	
160	27	0.01	136	259	-123	
170	26	0.01	138	275	-137	
180	25	0.01	139	291	-152	
190	24	0.01	141	307	-166	
200	23	0.01	142	323	-181	
210	22	0.01	144	340	-196	
220	21	0.01	145	356	-211	
230	20	0.01	146	372	-226	

counterpoint engineering

Modified Rational

Area: Building 2D&E

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Rainfall Data			
Location:	Toronto	a	59.700
Event	100 Year	b	0.000
		c	0.800

Site Data	
Area	0.810 ha
Runoff Coefficient	0.85
AC	0.69
Tc	10
Time Increment	10
Release Rate	99.2 L/s
Storage Required	228 m ³

Time	Rainfall Intensity	Storm Runoff	Runoff Volume	Released Volume	Storage Volume	
(min)	(mm/hr)	(m ³ /s)	(m ³)	(m ³)	(m ³)	
10	250	0.48	287	60	228	*****
20	144	0.28	330	119	211	
30	104	0.20	358	179	180	
40	83	0.16	379	238	141	
50	69	0.13	397	298	99	
60	60	0.11	411	357	54	
70	53	0.10	424	417	8	
80	47	0.09	436	476	-40	
90	43	0.08	446	536	-90	
100	40	0.08	456	595	-140	
110	37	0.07	464	655	-190	
120	34	0.07	473	714	-242	
130	32	0.06	480	774	-294	
140	30	0.06	487	833	-346	
150	29	0.05	494	893	-399	
160	27	0.05	501	952	-452	
170	26	0.05	507	1012	-505	
180	25	0.05	512	1071	-559	
190	24	0.05	518	1131	-613	
200	23	0.04	523	1191	-667	
210	22	0.04	528	1250	-722	
220	21	0.04	533	1310	-776	
230	20	0.04	538	1369	-831	

counterpoint engineering

Modified Rational

Area: Building 2F&G

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Rainfall Data			
Location:	Toronto	a	59.700
Event	100 Year	b	0.000
		c	0.800

Site Data	
Area	0.600 ha
Runoff Coefficient	0.85
AC	0.51
Tc	10
Time Increment	10
Release Rate	73.5 L/s
Storage Required	169 m ³

Time	Rainfall Intensity	Storm Runoff	Runoff Volume	Released Volume	Storage Volume	
(min)	(mm/hr)	(m ³ /s)	(m ³)	(m ³)	(m ³)	
10	250	0.35	213	44	169	*****
20	144	0.20	245	88	156	
30	104	0.15	265	132	133	
40	83	0.12	281	176	105	
50	69	0.10	294	220	73	
60	60	0.08	305	265	40	
70	53	0.07	314	309	6	
80	47	0.07	323	353	-30	
90	43	0.06	330	397	-66	
100	40	0.06	337	441	-103	
110	37	0.05	344	485	-141	
120	34	0.05	350	529	-179	
130	32	0.05	356	573	-218	
140	30	0.04	361	617	-256	
150	29	0.04	366	661	-295	
160	27	0.04	371	706	-335	
170	26	0.04	375	750	-374	
180	25	0.04	380	794	-414	
190	24	0.03	384	838	-454	
200	23	0.03	388	882	-494	
210	22	0.03	391	926	-535	
220	21	0.03	395	970	-575	
230	20	0.03	399	1014	-616	

counterpoint engineering

Modified Rational

Area: Building 2H&I

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Rainfall Data			
Location:	Toronto	a	59.700
Event	100 Year	b	0.000
		c	0.800

Site Data	
Area	0.950 ha
Runoff Coefficient	0.85
AC	0.81
Tc	10
Time Increment	10
Release Rate	116.4 L/s
Storage Required	267 m ³

Time	Rainfall Intensity	Storm Runoff	Runoff Volume	Released Volume	Storage Volume	
(min)	(mm/hr)	(m ³ /s)	(m ³)	(m ³)	(m ³)	
10	250	0.56	337	70	267	*****
20	144	0.32	387	140	248	
30	104	0.23	420	209	211	
40	83	0.19	445	279	166	
50	69	0.16	465	349	116	
60	60	0.13	482	419	64	
70	53	0.12	498	489	9	
80	47	0.11	511	559	-47	
90	43	0.10	523	628	-105	
100	40	0.09	534	698	-164	
110	37	0.08	545	768	-223	
120	34	0.08	554	838	-284	
130	32	0.07	563	908	-344	
140	30	0.07	572	977	-406	
150	29	0.06	579	1047	-468	
160	27	0.06	587	1117	-530	
170	26	0.06	594	1187	-593	
180	25	0.06	601	1257	-656	
190	24	0.05	608	1327	-719	
200	23	0.05	614	1396	-783	
210	22	0.05	620	1466	-846	
220	21	0.05	626	1536	-910	
230	20	0.05	631	1606	-975	

counterpoint engineering

Modified Rational

Area: Sumach ROW

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Rainfall Data			
Location:	Toronto	a	59.700
Event	100 Year	b	0.000
		c	0.800

Site Data	
Area	0.230 ha
Runoff Coefficient	0.85
AC	0.20
Tc	10
Time Increment	10
Release Rate	28.2 L/s
Storage Required	65 m ³

Time	Rainfall Intensity	Storm Runoff	Runoff Volume	Released Volume	Storage Volume	
(min)	(mm/hr)	(m ³ /s)	(m ³)	(m ³)	(m ³)	
10	250	0.14	82	17	65	*****
20	144	0.08	94	34	60	
30	104	0.06	102	51	51	
40	83	0.04	108	68	40	
50	69	0.04	113	85	28	
60	60	0.03	117	101	15	
70	53	0.03	120	118	2	
80	47	0.03	124	135	-11	
90	43	0.02	127	152	-25	
100	40	0.02	129	169	-40	
110	37	0.02	132	186	-54	
120	34	0.02	134	203	-69	
130	32	0.02	136	220	-83	
140	30	0.02	138	237	-98	
150	29	0.02	140	254	-113	
160	27	0.01	142	270	-128	
170	26	0.01	144	287	-143	
180	25	0.01	146	304	-159	
190	24	0.01	147	321	-174	
200	23	0.01	149	338	-189	
210	22	0.01	150	355	-205	
220	21	0.01	151	372	-220	
230	20	0.01	153	389	-236	

counterpoint engineering

Modified Rational

Area: Building 3J&K

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Rainfall Data			
Location:	Toronto	a	59.700
Event	100 Year	b	0.000
		c	0.800

Site Data	
Area	0.940 ha
Runoff Coefficient	0.85
AC	0.80
Tc	10
Time Increment	10
Release Rate	115.1 L/s
Storage Required	265 m ³

Time	Rainfall Intensity	Storm Runoff	Runoff Volume	Released Volume	Storage Volume	
(min)	(mm/hr)	(m ³ /s)	(m ³)	(m ³)	(m ³)	
10	250	0.56	334	69	265	*****
20	144	0.32	383	138	245	
30	104	0.23	416	207	208	
40	83	0.18	440	276	164	
50	69	0.15	460	345	115	
60	60	0.13	477	414	63	
70	53	0.12	492	484	9	
80	47	0.11	506	553	-47	
90	43	0.10	518	622	-104	
100	40	0.09	529	691	-162	
110	37	0.08	539	760	-221	
120	34	0.08	548	829	-281	
130	32	0.07	557	898	-341	
140	30	0.07	566	967	-402	
150	29	0.06	573	1036	-463	
160	27	0.06	581	1105	-524	
170	26	0.06	588	1174	-586	
180	25	0.06	595	1243	-649	
190	24	0.05	601	1313	-711	
200	23	0.05	607	1382	-774	
210	22	0.05	613	1451	-837	
220	21	0.05	619	1520	-901	
230	20	0.05	625	1589	-964	

counterpoint engineering

Modified Rational

Area: Tubman ROW

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Rainfall Data			
Location:	Toronto	a	59.700
Event	100 Year	b	0.000
		c	0.800

Site Data	
Area	0.180 ha
Runoff Coefficient	0.85
AC	0.15
Tc	10
Time Increment	10
Release Rate	22.0 L/s
Storage Required	51 m ³

Time	Rainfall Intensity	Storm Runoff	Runoff Volume	Released Volume	Storage Volume	
(min)	(mm/hr)	(m ³ /s)	(m ³)	(m ³)	(m ³)	
10	250	0.11	64	13	51	*****
20	144	0.06	73	26	47	
30	104	0.04	80	40	40	
40	83	0.04	84	53	31	
50	69	0.03	88	66	22	
60	60	0.03	91	79	12	
70	53	0.02	94	93	2	
80	47	0.02	97	106	-9	
90	43	0.02	99	119	-20	
100	40	0.02	101	132	-31	
110	37	0.02	103	146	-42	
120	34	0.01	105	159	-54	
130	32	0.01	107	172	-65	
140	30	0.01	108	185	-77	
150	29	0.01	110	198	-89	
160	27	0.01	111	212	-100	
170	26	0.01	113	225	-112	
180	25	0.01	114	238	-124	
190	24	0.01	115	251	-136	
200	23	0.01	116	265	-148	
210	22	0.01	117	278	-160	
220	21	0.01	119	291	-172	
230	20	0.01	120	304	-185	

counterpoint engineering

Modified Rational

Area: Building 4L&M

Project Name: Regent Park Phase 4 & 5

Project Number: 21123

Rainfall Data			
Location:	Toronto	a	59.700
Event	100 Year	b	0.000
		c	0.800

Site Data	
Area	0.960 ha
Runoff Coefficient	0.85
AC	0.82
Tc	10
Time Increment	10
Release Rate	117.6 L/s
Storage Required	270 m ³

Time	Rainfall Intensity	Storm Runoff	Runoff Volume	Released Volume	Storage Volume	
(min)	(mm/hr)	(m ³ /s)	(m ³)	(m ³)	(m ³)	
10	250	0.57	341	71	270	*****
20	144	0.33	391	141	250	
30	104	0.24	424	212	213	
40	83	0.19	450	282	167	
50	69	0.16	470	353	117	
60	60	0.14	488	423	64	
70	53	0.12	503	494	9	
80	47	0.11	516	564	-48	
90	43	0.10	529	635	-106	
100	40	0.09	540	706	-166	
110	37	0.08	550	776	-226	
120	34	0.08	560	847	-287	
130	32	0.07	569	917	-348	
140	30	0.07	578	988	-410	
150	29	0.07	586	1058	-473	
160	27	0.06	593	1129	-536	
170	26	0.06	600	1199	-599	
180	25	0.06	607	1270	-663	
190	24	0.05	614	1340	-727	
200	23	0.05	620	1411	-791	
210	22	0.05	626	1482	-855	
220	21	0.05	632	1552	-920	
230	20	0.05	638	1623	-985	

counterpoint engineering

Modified Rational

Area: River

Project Name: #REF!

Project Number: #REF!

Rainfall Data			
Location:	Toronto	a	59.700
Event	100 Year	b	0.000
		c	0.800

Site Data	
Area	0.940 ha
Runoff Coefficient	0.85
AC	0.80
Tc	10
Time Increment	10
Release Rate	115.1 L/s
Storage Required	265 m ³

Time	Rainfall Intensity	Storm Runoff	Runoff Volume	Released Volume	Storage Volume	
(min)	(mm/hr)	(m ³ /s)	(m ³)	(m ³)	(m ³)	
10	250	0.56	334	69	265	*****
20	144	0.32	383	138	245	
30	104	0.23	416	207	208	
40	83	0.18	440	276	164	
50	69	0.15	460	345	115	
60	60	0.13	477	414	63	
70	53	0.12	492	484	9	
80	47	0.11	506	553	-47	
90	43	0.10	518	622	-104	
100	40	0.09	529	691	-162	
110	37	0.08	539	760	-221	
120	34	0.08	548	829	-281	
130	32	0.07	557	898	-341	
140	30	0.07	566	967	-402	
150	29	0.06	573	1036	-463	
160	27	0.06	581	1105	-524	
170	26	0.06	588	1174	-586	
180	25	0.06	595	1243	-649	
190	24	0.05	601	1313	-711	
200	23	0.05	607	1382	-774	
210	22	0.05	613	1451	-837	
220	21	0.05	619	1520	-901	
230	20	0.05	625	1589	-964	

Counterpoint Engineering

Water Balance

Regent Park Phases 4 & 5

City of Toronto's Green Standard Tier 1

Section QW 2.2

Initial Abstraction Asphalt, I	1 mm
Initial Abstraction Pervious, P	5 mm
Initial Abstraction Roof, R	1 mm
Toronto's small design rainfall event has 5mm excess rainfall	

Type of Area	Area	Units	% Redevelopment Area
Non-Green Roof Building Area	1.049	ha	51%
Asphalt / Impervious	0.207	ha	10%
Pervious / Green Roof Area	0.711	ha	34%
Total Area	2.070	ha	95%

Initial Abstraction= Percent Impervious (Roof) *R + Percent Impervious (Asphalt)* I + Percent Previous Green Roof * P
Initial Abstraction= 0.51 x 1mm + 0.10 x 1mm + 0.34 x 5mm

Initial Abstraction (credit)= 2.32 mm

Required Development Retention = (Excess Rainfall- Initial Abstraction) * (Total Development Area)
Required Development Retention = (5mm - 2.32 mm) x (2.070)ha

Required Development Retention (debit)= 55.4 m³

Counterpoint Engineering

Water Balance

Regent Park Phases 4 & 5

City of Toronto's Green Standard Tier 1

Section QW 2.2

Initial Abstraction Asphalt, I	1 mm
Initial Abstraction Pervious, P	5 mm
Initial Abstraction Roof, R	1 mm
Toronto's small design rainfall event has 5mm excess rainfall	

Type of Area	Area	Units	% Redevelopment Area
Non-Green Roof Building Area	0.888	ha	45%
Asphalt / Impervious	0.495	ha	25%
Pervious / Green Roof Area	0.597	ha	30%
Total Area	1.980	ha	100%

Initial Abstraction= Percent Impervious (Roof) *R + Percent Impervious (Asphalt)* I + Percent Previous Green Roof * P
Initial Abstraction= 0.45 x 1mm + 0.25 x 1mm + 0.30 x 5mm

Initial Abstraction (credit)= 2.21 mm

Required Development Retention = (Excess Rainfall- Initial Abstraction) * (Total Development Area)
Required Development Retention = (5mm - 2.21 mm) x (1.980)ha

Required Development Retention (debit)= 55.3 m³

Counterpoint Engineering

Water Balance

Regent Park Phases 4 & 5

City of Toronto's Green Standard Tier 1

Section QW 2.2

Initial Abstraction Asphalt, I	1 mm
Initial Abstraction Pervious, P	5 mm
Initial Abstraction Roof, R	1 mm
Toronto's small design rainfall event has 5mm excess rainfall	



Type of Area	Area	Units	% Redevelopment Area
Non-Green Roof Building Area	1.002	ha	48%
Asphalt / Impervious	0.416	ha	20%
Pervious / Green Roof Area	0.662	ha	32%
Total Area	2.080	ha	100%

Initial Abstraction= Percent Impervious (Roof) *R + Percent Impervious (Asphalt)* I + Percent Previous Green Roof * P
Initial Abstraction= 0.48 x 1mm + 0.20 x 1mm + 0.32 x 5mm

Initial Abstraction (credit)= 2.27 mm

Required Development Retention = (Excess Rainfall- Initial Abstraction) * (Total Development Area)
Required Development Retention = (5mm - 2.27 mm) x (2.080)ha

Required Development Retention (debit)= 56.7 m³



- LEGEND**
- 0.27 DENOTES DRAINAGE AREA IN ha
 - 0.50 DENOTES STORM RUN-OFF
 - ▬ STORM DRAINAGE BOUNDARY
 - ▬ STORM OVERFLOW SEWER (SOS)
 - ▬ SUB-STORM DRAINAGE BOUNDARY
 - ▬ EXISTING STORM SEWER
 - ▬ PROPOSED STORM SEWER
 - ▬ FUTURE STORM SEWER
 - ⇨ EXISTING OVERLAND FLOW DIRECTION
 - ⇨ PROPOSED OVERLAND FLOW DIRECTION
 - ▭ PHASE 3

BENCHMARK:
 ELEVATIONS ARE OF GEODETIC ORIGIN AND ARE DERIVED FROM THE CITY OF TORONTO BENCH MARKS No. CT-753, CT-756, CT-757 AND CT-758 HAVING AN ELEVATION OF 91.405, 86.133, 88.169 AND 88.722 METERS RESPECTIVELY.

DIGITAL INFORMATION
 ALL SURVEY INFORMATION EXISTING IN THESE PLANS WERE PROVIDED BY R. AVIS SURVEYING INC. DATE NOVEMBER 16, 2012.
 EXISTING UTILITY INFORMATION SHOWN IN THESE PLANS WERE PROVIDED BY TPUC AND LOCATIONS AND DEPTHS ARE APPROXIMATE.

No.	DATE	REVISIONS	INITIAL	SIGNED
9	24/04/15	6TH SUBMISSION TO CITY	MZH	MZH
8	06/03/15	5TH SUBMISSION TO CITY	MZH	MZH
7	03/12/14	ISSUED FOR TENDER ADDENDUM # 2	MZH	MZH
6	03/12/14	4TH SUBMISSION TO CITY	MZH	MZH
5	06/11/14	ISSUED FOR TENDER	LDS	LDS
4	02/10/14	3RD SUBMISSION TO CITY	LDS	LDS
3	31/07/14	2ND SUBMISSION TO CITY	LDS	LDS
2	05/06/14	REVISED STREET O	LDS	LDS
1	09/05/14	1ST SUBMISSION TO CITY	LDS	LDS

DILLON CONSULTING
 235 Yorkland Blvd., Suite 800, Toronto, ON M2J 4Y8
 Phone: (416) 229-4846 Fax: (416) 229-4692

PROFESSIONAL ENGINEER
 M. Z. HOSSAIN
 100133333
 April 24, 2015
 PROVINCE OF ONTARIO

Toronto ENGINEERING & CONSTRUCTION SERVICES
 Development Engineering
 ACCEPTED TO BE IN ACCORDANCE WITH THE CITY OF TORONTO STANDARDS.
 THIS ACCEPTANCE IS NOT TO BE CONSTRUED AS VERIFICATION OF ENGINEERING CONTENT.
 MANAGER, DEVELOPMENT ENGINEERING DATE: **MAY 19 2015**

REGENT PARK - PHASE 3
STORM DRAINAGE PLAN

DESIGN	MZH	DRAWN	GCC	CHECKED	TY	JOB No. 12-6942
SCALE:	1:1250	DWG:	SD-1			
DATE:	APRIL 2015	SHEET	43 OF 69			



Appendix B

Sanitary Servicing

Counterpoint Engineering Inc.

Project: Regent Park Phases 4&5
 Project No: 21123
 Location: River
 Site Area: 2.08 ha

Approved Sanitary Flow Calculations Block 8 & 10 DWG SS-1

	Population S / 1BR / 1B + D	Population 2BR / 2BR + D	Population 3BR / 3BR + D	Population Over 3B	TOTAL POPULATION
Residential	0	0	0	0	2130
Retail	-	-	-	-	0
Office	-	-	-	-	0
Total Equivalent Population					2130

Plea flow Design Parameters

Residential Average flow	240 litres/person/day
Commercial/Office Average flow	250 litres/person/day
Infiltration	0.26 litres/second/ha

Harmon Peaking Factor

$$PF = 1 + (14/(4+(P/1000)^{1/2}))$$

Residential Population	Harmon Peak Factor
2130	3.56

Residential Flow	21.09	l/s	*peaked flows
Commercial and Office Flow	0.00	l/s	
Infiltration	0.54	l/s	
Groundwater Flows	0.00	l/s	

Total Peak Flow	21.63	l/s
------------------------	--------------	------------

Location: Sumack
 Site Area: 2.17 ha

Approved Sanitary Flow Calculations Block 6 & 7 DWG SS-1

	Population S / 1BR / 1B + D	Population 2BR / 2BR + D	Population 3BR / 3BR + D	Population Over 3B	TOTAL POPULATION
Residential	0	0	0	0	1202
Retail	-	-	-	-	0
Office	-	-	-	-	0
Total Equivalent Population					1202

Plea flow Design Parameters

Residential Average flow	240 litres/person/day
Commercial/Office Average flow	250 litres/person/day
Infiltration	0.26 litres/second/ha

Harmon Peaking Factor

$$PF = 1 + (14/(4+(P/1000)^{1/2}))$$

Residential Population	Harmon Peak Factor
1202	3.75

Residential Flow	12.51	l/s	*peaked flows
Commercial and Office Flow	0.00	l/s	
Infiltration	0.56	l/s	
Groundwater Flows	0.00	l/s	

Flow	13.08	l/s
-------------	--------------	------------

Location: Sackville
 Site Area: 2.13 ha

Approved Sanitary Flow Calculations Block 2, 4 & 5 DWG SS-1

	Population S / 1BR / 1B + D	Population 2BR / 2BR + D	Population 3BR / 3BR + D	Population Over 3B	TOTAL POPULATION
Residential	0	0	0	0	1967
Retail	-	-	-	-	0
Office	-	-	-	-	0
Total Equivalent Population					1967

Plea flow Design Parameters

Residential Average flow	240 litres/person/day
Commercial/Office Average flow	250 litres/person/day
Infiltration	0.26 litres/second/ha

Harmon Peaking Factor

$$PF = 1 + (14/(4+(P/1000)^{1/2}))$$

Residential Population	Harmon Peak Factor
1967	3.59

Residential Flow	19.62	l/s	*peaked flows
Commercial and Office Flow	0.00	l/s	
Infiltration	0.55	l/s	
Groundwater Flows	0.00	l/s	

Flow	20.18	l/s
-------------	--------------	------------

Counterpoint Engineering Inc.

Project: Regent Park Phases 4&5
Project No: 21123
Location: Sackville
Site Area: 2.13 ha

Proposed Sanitary Flow Calculations

As per Design Criteria for Sewers and Watermains - Second Edition November 2021 City of Toronto
Design flow = average daily dry weather flow x peaking factor + infiltration

Persons Per Unit and per Land Use

1BR/1BR+Den	1.4	ppu
2BR/2BR+Den/	2.1	ppu
3BR/3BR+Den	3.1	ppu
Over 3B	5.1	ppu
Commercial / Retail	1.1	persons/100m ²
Offices	3.3	persons/100m ²

	Residential Units				Total Units	Office	Retail
	S / 1B / 1B+D	2B / 2B + D	3B / 3B+D	Over 3B		Area (m ²)	Area (m ²)
Outlet to Sackville							
Block 1							
Building A	21	107	111	35	274	2473	
Building B	187	65	17	0	269	1334	
Building C	321	111	30	0	462		
Block 2							
Building D	151	52	14	0	217	1594	
Building E	211	73	19	0	303	623	
TOTAL UNITS / AREA (m²)	891	408	191	35	1525	6024	0.0

	Population S / 1BR / 1B + D	Population 2BR / 2BR + D	Population 3BR / 3BR + D	Population Over 3B	TOTAL POPULATION
Residential	1248	857	593	179	2877
Retail		-	-	-	0
Office		-	-	-	199
Total Equivalent Population					3076

Plea flow Design Parameters

Residential Average flow	240	litres/person/day
Commercial/Office Average flow	250	litres/person/day
Infiltration	0.26	litres/second/ha

Harmon Peaking Factor

$$PF = 1 + (14/(4+(P/1000)^{1/2}))$$

Residential Population	Harmon Peak Factor
2877	3.46

Residential Flow	27.63	l/s	*peaked flows
Commercial and Office Flow	0.58	l/s	
Infiltration	0.55	l/s	
Groundwater Flows	0.00	l/s	

Total Peak Flow	28.76	l/s
------------------------	--------------	------------

Counterpoint Engineering Inc.

Project: Regent Park Phases 4&5
Project No: 21123
Location: Sumach
Site Area: 2.2 ha

Proposed Sanitary Flow Calculations

As per Design Criteria for Sewers and Watermains - Second Edition November 2021 City of Toronto
Design flow = average daily dry weather flow x peaking factor + infiltration

Persons Per Unit and per Land Use

1BR/1BR+Den	1.4	ppu
2BR/2BR+Den/	2.1	ppu
3BR/3BR+Den	3.1	ppu
Over 3B	5.1	ppu
Commercial / Retail	1.1	persons/100m ²
Offices	3.3	persons/100m ²

	Residential Units				Total Units	Office	Retail
	S / 1B / 1B+D	2B / 2B + D	3B / 3B+D	Over 3B		Area (m ²)	Area (m ²)
Outlet to Sumach							
Block 2							
Building F	0	0	0	0	0	4554	
Building G	0	0	0	0	0	405	
Building H	17	64	64	13	158	1662	
Building I	13	70	91	11	185	605	
TOTAL UNITS / AREA (m²)	30	134	155	24	343	7226	0.0

	Population S / 1BR / 1B + D	Population 2BR / 2BR + D	Population 3BR / 3BR + D	Population Over 3B	TOTAL POPULATION
Residential	42	282	481	123	928
Retail	-	-	-	-	0
Office	-	-	-	-	239
Total Equivalent Population					1167

Plea flow Design Parameters

Residential Average flow	240	litres/person/day
Commercial/Office Average flow	250	litres/person/day
Infiltration	0.26	litres/second/ha

Harmon Peaking Factor

$$PF = 1 + (14 / (4 + (P/1000)^{1/2}))$$

Residential Population	Harmon Peak Factor
928	3.82

Residential Flow	9.85	l/s	*peaked flows
Commercial and Office Flow	0.69	l/s	
Infiltration	0.58	l/s	
Groundwater Flows	0.00	l/s	

Flow	11.12	l/s
-------------	--------------	------------

Counterpoint Engineering Inc.

Project: Regent Park Phases 4&5
Project No: 21123
Location: River
Site Area: 2.08 ha

Proposed Sanitary Flow Calculations

As per Design Criteria for Sewers and Watermains - Second Edition November 2021 City of Toronto
Design flow = average daily dry weather flow x peaking factor + infiltration

Persons Per Unit and per Land Use

1BR/1BR+Den	1.4	ppu
2BR/2BR+Den/	2.1	ppu
3BR/3BR+Den	3.1	ppu
Over 3B	5.1	ppu
Commercial / Retail	1.1	persons/100m ²
Offices	3.3	persons/100m ²

	Residential Units				Total Units	Office	Retail
	S / 1B / 1B+D	2B / 2B + D	3B / 3B+D	Over 3B		Area (m ²)	Area (m ²)
Outlet to River							
Block 3							
Building J	187	66	18	0	271	1294	
Building K	314	110	30	0	454		
Block 4							
Building L	55	111	118	27	311	953	
Building M	62	123	129	28	342	955	
TOTAL UNITS / AREA (m²)	618	410	295	55	1378	3202	0.0

	Population S / 1BR / 1B + D	Population 2BR / 2BR + D	Population 3BR / 3BR + D	Population Over 3B	TOTAL POPULATION
Residential	866	861	915	281	2923
Retail		-	-	-	0
Office		-	-	-	106
Total Equivalent Population					3029

Plea flow Design Parameters

Residential Average flow	240	litres/person/day
Commercial/Office Average flow	250	litres/person/day
Infiltration	0.26	litres/second/ha

Harmon Peaking Factor

$$PF = 1 + (14/(4+(P/1000)^{1/2}))$$

Residential Population	Harmon Peak Factor
2923	3.45

Residential Flow	28.03	l/s	*peaked flows
Commercial and Office Flow	0.31	l/s	
Infiltration	0.54	l/s	
Groundwater Flows	0.00	l/s	



Total Peak Flow	28.88	l/s
------------------------	--------------	------------

PARK REVITALIZATION
LOADING TO THE EXISTING COMBINED SEWERS

Residential Average Daily Flow= 240.0 L/cap/day
 Peak Extraneous Flow= 5.0 L/ha/s

T initial = 10.00 min
 a= 21.80
 b= 0.00
 c= 0.78

Combined Sewer System	Regent Park SAN Sewer			Development Phase		Proposed Area			EXISTING SANITARY FLOW					EXISTING STORM SEWER			TOTAL EXISTING FLOW
	Location	From	To	No.	No.	Block Area	Retail	Bldg Footprint	Residential Pop (pop/ha)	Harmon Coeff. M	Peak Flow	Infiltration Flow 5 L/ha/s	TOTAL FLOW	RUN-OFF	Intensity	TOTAL FLOW	
						(ha)	(ha)	(ha)	86.0		(L/s)	(L/s)	(L/s)		(mm/hr)	(L/s)	(L/s)
Sackville				Phase 4 & 5	1	2.07							13.2	0.5	88.19	253.55	266.75
					2	0.68									4.29	0.5	88.19
																Total	354.33
Sumach				Phase 4 & 5	2	1.3							8.27	0.5	88.19	159.23	167.50
River				Phase 4 & 5	3	2.08							12.07	0.5	88.19	254.77	266.84



- LEGEND**
- 1.12
724 DENOTES DRAINAGE AREA IN ha
DENOTES POPULATION NUMBER
 - EX. 2400mm Cir. B.C. San. Sewer
 - ▬ SANITARY DRAINAGE BOUNDARY
 - ▬ SANITARY DRAINAGE BOUNDARY PER BLOCK
 - 12A PROPOSED SANITARY MANHOLE
 - Ex. 1A EXISTING SANITARY MANHOLE

BENCHMARK:
ELEVATIONS ARE OF GEODETIC ORIGIN AND ARE DERIVED FROM THE CITY OF TORONTO BENCH MARKS No. CT-753, CT-756, CT-757 AND CT-758 HAVING AN ELEVATION OF 91.405, 86.133, 88.169 AND 88.722 METERS RESPECTIVELY.

DIGITAL INFORMATION
ALL SURVEY INFORMATION EXISTING IN THESE PLANS WERE PROVIDED BY R. AVIS SURVEYING INC. DATE NOVEMBER 16, 2012.
EXISTING UTILITY INFORMATION SHOWN IN THESE PLANS WERE PROVIDED BY TRUCC AND LOCATIONS AND DEPTHS ARE APPROXIMATE.

No.	DATE	REVISIONS	INITIAL	SIGNED
9	24/04/15	6TH SUBMISSION TO CITY	MZH	MZH
8	06/03/15	5TH SUBMISSION TO CITY	MZH	MZH
7	03/12/14	ISSUED FOR TENDER ADDENDUM # 2	MZH	MZH
6	03/12/14	4TH SUBMISSION TO CITY	MZH	MZH
5	06/11/14	ISSUED FOR TENDER	LDS	LDS
4	02/10/14	3RD SUBMISSION TO CITY	LDS	LDS
3	31/07/14	2ND SUBMISSION TO CITY	LDS	LDS
2	05/06/14	REVISED STREET O	LDS	LDS
1	09/05/14	1ST SUBMISSION TO CITY	LDS	LDS

DILLON CONSULTING
235 Yorkland Blvd., Suite 800, Toronto, ON M2J 4Y8
Phone: (416) 229-4646 Fax: (416) 229-4692

Licensed Professional Engineer
M. Z. HOGGAN
180155533
April 24, 2015
PROVINCE OF ONTARIO

Toronto ENGINEERING & CONSTRUCTION SERVICES
Development Engineering
ACCEPTED TO BE IN ACCORDANCE WITH THE CITY OF TORONTO STANDARDS.
THIS ACCEPTANCE IS NOT TO BE CONSTRUED AS VERIFICATION OF ENGINEERING CONTENT.

MANAGER, DEVELOPMENT ENGINEERING *[Signature]* DATE: **MAY 19 2015**

**REGENT PARK - PHASE 3
SANITARY DRAINAGE PLAN**

DESIGN	MZH	DRAWN	DTM	CHECKED	LDS	JOB No.	12-6942
SCALE:	1:1250			DWG:	SS-1		
DATE:	APRIL 2015			SHEET	44 OF 69		

From Dillon Report

**- Estimated Sanitary and
Storm Flow Discharging to the Existing
Combined Sewers**

REGENT PARK REVITALIZATION
ESTIMATED SANITARY FLOW DISCHARGING TO THE EXISTING COMBINED SEWERS

T initial = 10.00 min
a= 732.00
b= 5.90
c= 0.81

Residential Average Daily Flow= 318.0 L/cap/day
Peak Extraneous Flow= 5.0 L/ha/s

Combined Sewer System	Regent Park SAN Sewer			Development Phase	Development Block	Proposed Area			EXISTING SANITARY FLOW					EXISTING STORM SEWER			TOTAL EXISTING FLOW (L/s)
	Location	From	To			No.	No.	Block Area (ha)	Retail (ha)	Bldg Footprint (ha)	Residential Pop (pop/ha) 170	Harmon Coeff. M	Peak Flow (L/s)	Infiltration Flow 5 L/ha/s (L/s)	TOTAL FLOW (L/s)	RUN-OFF	
SACKVILLE STREET COMBINED SEWER																	
Sackville	Oak	Parliament	Sackville	Phase 4	1	0.83		0.383	71.4	4.28	1.12	4.15	5.27	0.5	78.30	32.50	37.77
				Phase 4	2	0.47		0.348	40.6	4.33	0.65	2.36	3.01	0.5	78.30	18.48	21.49
				Phase 1	3	0.27		0.117	200.1				4.39		78.30	0.00	4.39
				Phase 4	4	0.77		0.562	66.5	4.29	1.05	3.87	4.92	0.5	78.30	30.29	35.21
Sackville	Oak	Street H	Sackville	Phase 5	5	0.68		0.582	58.1	4.30	0.92	3.38	4.29	0.5	78.30	26.43	30.72
Sackville	Cole	Parliament	Sackville	Phase 1	11	0.57	0.11	0.463	283.7				6.20		78.30	0.00	6.20
				Phase 1	12	0.58		0.580	485.3				10.21		78.30	0.00	10.21
				Phase 1	13	0.69	0.32	0.690	711.3				14.64		78.30	0.00	14.64
				Phase 1	14	0.69	0.18	0.243	822.0				16.70		78.30	0.00	16.70
			Community Centre	Phase 1	15	1.27	0.64	0.635	69.9				1.97		78.30	0.00	1.97
TO SACKVILLE STREET FROM GERRARD TO WEIR NORTH OF DUNDAS SOS									2808.8				72			107.69	
				Regent Street 30		0.43		0.310	37.0	4.34	0.59	2.15	2.74	0.5	78.30	16.85	19.60
				Ex. Church SAN		0.30		0.220	25.5	4.37	0.41	1.48	1.89	0.5	78.30	11.62	13.51
				Phase 2	20	0.31		0.309	257.6				5.59		78.30	0.00	5.59
				Phase 2	21	0.54		0.536	416.3				8.84		78.30	0.00	8.84
				Phase 2	22	0.53		0.531	266.8				5.83		78.30	0.00	5.83
				Phase 2	23	0.28		0.145	101.2				2.31		78.30	0.00	2.31
				Phase 2	24	1.04	0.70	1.200	1052.2				19.61		78.30	0.00	19.61
				Phase 2	38	0.44		0.440	114.1				2.63		78.30	0.00	2.63
TO SACKVILLE STREET FROM DUNDAS STREET EAST TO SHUTER STREET									2270.8				49			28.47	
TOTAL SANITARY FLOW TO SACKVILLE STREET COMBINED SEWER						10.69			5,080				121			136.17	257

Combined Sewer System	Regent Park SAN Sewer			Development Phase	Development Block	Proposed Area			EXISTING SANITARY FLOW					EXISTING STORM SEWER			TOTAL EXISTING FLOW (L/s)
	Location	From	To			No.	No.	Block Area (ha)	Retail (ha)	Bldg Footprint (ha)	Residential Pop (pop/ha)	Harmon Coeff. M	Peak Flow (L/s)	Infiltration Flow 5 L/ha/s (L/s)	TOTAL FLOW (L/s)	RUN-OFF	
<i>SUMACH STREET COMBINED SEWER</i>																	
Sumach	Oak	Street I	Sumach	Phase 5	6	0.66		0.582	56.8	4.30	0.90	3.30	4.20	0.5	78.30	25.84	30.04
				Phase 5	7	0.64		0.582	55.0	4.31	0.87	3.20	4.07	0.5	78.30	25.06	29.13
			Aquatic Center	Phase 2	15	1.21			1350.0				26.52		78.30	0.00	26.52
TO SUMACH STREET FROM GERRARD TO WEIR NORTH OF DUNDAS STREET EAST									1461.8	3.69			35			50.90	
				Phase 2	25	1.17		1.168	1729.6	4.50	0.00	0.00	0.00		78.30	0.00	33.04
TO SUMACH STREET FROM DUNDAS STREET TO WEIR NORTH OF HLI									1729.6	3.63			33		0.00		
				Phase 3	26	0.33	0.16	0.480	28.4	4.36	0.46	1.65	2.11	0.5	78.30	12.95	15.06
				Phase 3	27	0.33	0.15	0.471	28.0	4.36	0.45	1.63	2.07	0.5	78.30	12.72	14.80
				Phase 3	28	0.23		0.301	19.7	4.38	0.32	1.15	1.46	0.5	78.30	8.97	10.43
				Phase 3	32	0.46		0.228	39.6	4.33	0.63	2.30	2.93	0.5	78.30	18.01	20.94
				Phase 3	35	0.33			28.4	4.36	0.46	1.65	2.11	0.5	78.30	12.92	15.03
TO SUMACH STREET SOUTH OF MARK STREET									144.0	4.20			11			65.57	
TOTAL SANITARY FLOW TO SUMACH STREET COMBINED SEWER						5.35			3,191				79		116	195	
<i>RIVER STREET COMBINED SEWER</i>																	
				Phase 5	8	0.96		0.659	82.6	4.27	1.30	4.80	6.10	0.5	78.30	37.59	43.68
				Phase 5	10	0.94		0.657	80.8	4.27	1.27	4.70	5.97	0.5	78.30	36.80	42.77
				Phase 3	16	0.89	0.12	0.708	76.3	4.27	1.20	4.44	5.63	0.5	78.30	34.73	40.36
				Phase 3	17	0.87	0.11	0.594	74.7	4.28	1.18	4.35	5.52	0.5	78.30	34.02	39.54
TO RIVER STREET WEIR NORTH OF SOS									314.4				23		143.14		
				Phase 3	30	0.49		0.679	42.1	4.33	0.67	2.45	3.12	0.5	78.30	19.18	22.31
TO RIVER STREET WEIR NORTH OF HLI									42.1				3		19.18		
TOTAL SANITARY FLOW TO RIVER STREET COMBINED SEWER						4.15			357				26		162	189	
TOTAL PROPOSED SANITARY FLOW GENERATED FROM THE REGENT PARK REDEVELOPMENT													226		415	641	



Appendix C

Water Servicing

Counterpoint Engineering Inc.
Water Demand Design Calculations

Project: Regent Park Phases 4&5
Project No: 21123
Location: Toronto, Ontario
Site Area: 6.200 ha

Persons Per Unit and per Land Use

1BR/1BR+Den	1.4	ppu
2BR/2BR+Den/	2.1	ppu
3BR/3BR+Den	3.1	ppu
Over 3B	5.1	ppu
Hotel	1.0	person/bed
Commercial / Retail	1.1	persons/100m ²
Offices	3.3	persons/100m ²

	Residential Units				Total Units	Office	Retail
	S / 1B / 1B+D	2B / 2B + D	3B / 3B+D	Over 3B		Area (m ²)	Area (m ²)
1A	21	107	111	35	274	2473	
2B	187	65	17	0	269	1334	
2C	321	111	30	0	462		
3D	151	52	14	0	217	1594	
3E	211	73	19	0	303	623	
3F	0				0	4554	
3G	0				0	405	
3H	17	64	64	13	158	1662	
3I	13	70	91	11	185	605	
4J	187	66	18		271	1294	
4K	314	110	30		454		
5L	55	111	118	27	311	953	
5M	62	123	129	28	342	955	
TOTAL UNITS / AREA (m²)	1539	952	641	114	3246	16452	0.0

	Population S / 1BR / 1B + D	Population 2BR / 2BR + D	Population 3BR / 3BR + D	Over 3B	Total Population
Residential	2155	2000	1988	582	6725
Office					545
Retail	-	-		-	0
Total Equivalent Population					7270

City of Toronto Watermain Guidelines

Per Capita Demand

Single Family	320	(l/capita/day)
Multi-Unit	190	(l/capita/day)

Peaking Factors

Land Use	Minimum Hour	Maximum Hour	Maximum Day
Residential	0.70	2.48	1.65
Commercial	0.84	1.20	1.10
Industrial	0.84	0.90	1.10
Institutional	0.84	0.90	1.10
Apartment	0.84	2.50	1.30

*Values used for Residential (Multi-Unit) Land Use

Water Demand based on Equivalent Population

Land Use	Population	Minimum Hour (L/min)	Maximum Hour (L/min)	Maximum Day (L/min)	Fire Flow Required (L/min)	Max Day + Fire Flow (L/min)
Apartment	6725	745.4	2218.3	1153.5	-	-
Office	545	60.4	86.3	79.1		
Retail	0	0.0	0.0	0.0	-	-
Totals	7270	806	2305	1233	9000	10233

* See attached table in Appendix B for Fire Flow Duration

Counterpoint Engineering Inc.

REQUIRED FIRE FLOW WORKSHEET - PROPOSED DEVELOPMENT

Fire Underwriters Survey

Project : Regent Park Phases 4&5
Project No: 21123

Guide for Determination of Required Flow Copyright I.S.O

$$F = 220C\sqrt{A}$$

where

- F = the required fire flow in litres per minute.
 C = coefficient related to the type of construction.
 = 1.5 for wood frame construction (structure essentially all combustible).
 = 1.0 for ordinary construction (brick or other masonry walls, combustible floor and interior).
 = 0.8 for non-combustible construction (unprotected metal structural components, masonry or metal walls).
 = 0.6 for fire-resistive construction (fully protected frame, floors, roof).
 A = The total floor area in square metres (including all storeys, but excluding basements at least 50 percent below grade) in the building being considered.

Type of Construction	Class Factor
WF Wood Frame	1.5
OC Ordinary Construction	1.0
NC Non-Combustible	0.8
FC Fire-Resistive	0.6

Area Notes for Fire Resistive Buildings (from FUS manual, 1999):

If Vertical Openings are inadequately protected (less than 1-hour fire rating): Area is the total of the two largest adjoining floors (above ground level) plus 50% of the area of each of the next 8 adjoining floors above that.

Contents	% Reduction
NC Non-Combustible	25
LC Limited Combustible	15
C Combustible	0
FB Free Burning	15
RB Rapid Burning	25

If Vertical Openings are adequately protected (at least 1-hour fire rating): Area is the total of the largest floor (above ground level) plus 25% of the area of each of the next 2 immediately adjoining floors above that.

1) **Fire Flow** Building 1A
 Type of Construction: nc GF Area 3174 m²
 C= 0.8
 A* = 4761 m²
 F = 12,144 L/min
 12,000 L/min (round to the nearest 1,000L/min)

Note: Assuming Ordinary Construction building. Assuming Vertical Openings are adequately protected. Area is the total of the largest floor (level 1) plus 25% of the next 2 adjoining floors above.

2) **Occupancy Reduction/Surcharge**
 Contents Factor: LC
 Reduction/Surcharge of -15% = -1,822 L/min
 F = 12000L/min + -1822 L/min = 10,178 L/min

3) **System Type Reduction**
 NFPA 13 Sprinkler: YES 30%
 Standard Water Supply: YES 10%
 Fully Supervised: YES 10%
 Total 50%
 Reduction of 50% L/min = 5,089 L/min
 F = 10178L/min - 5,089 L/min = 5,089 L/min

4) **Separation Charge**

Building Face	Dist(m)	Charge
North	27	10%
East	17.5	15%
South	16.5	15%
West	23	10%
Total		50%

50% of 10178 L/min = 5,089 L/min
 (max exposure charge can be 75%)

Separation	Charge	Separation	Charge
0 to 3m	25%	20.1 to 30 m	10%
3.1 to 10m	20%	30.1 to 45m	5%
10.1 to 20m	15%		

F = 5089L/min + 5089L/min = 10,178 L/min (2,000L/min < F < 45,000L/min)

F =	10,000 L/min	(round to the nearest 1,000L/min)
F =	167 L/s	
F =	2,642 gpm	

Counterpoint Engineering Inc.

REQUIRED FIRE FLOW WORKSHEET - PROPOSED DEVELOPMENT

Fire Underwriters Survey

Project : **Regent Park Phases 4&5**
 Project No: **21123**

Guide for Determination of Required Flow Copyright I.S.O

$$F = 220C\sqrt{A}$$

where

- F = the required fire flow in litres per minute.
- C = coefficient related to the type of construction.
 - = 1.5 for wood frame construction (structure essentially all combustible).
 - = 1.0 for ordinary construction (brick or other masonry walls, combustible floor and interior).
 - = 0.8 for non-combustible construction (unprotected metal structural components, masonry or metal walls).
 - = 0.6 for fire-resistive construction (fully protected frame, floors, roof).
- A = The total floor area in square metres (including all storeys, but excluding basements at least 50 percent below grade) in the building being considered.

Type of Construction	Class Factor
WF Wood Frame	1.5
OC Ordinary Construction	1.0
NC Non-Combustible	0.8
FC Fire-Resistive	0.6

Area Notes for Fire Resistive Buildings (from FUS manual, 1999):

If Vertical Openings are inadequately protected (less than 1-hour fire rating): Area is the total of the two largest adjoining floors (above ground level) plus 50% of the area of each of the next 8 adjoining floors above that.

Contents	% Reduction
NC Non-Combustible	25
LC Limited Combustible	15
C Combustible	0
FB Free Burning	15
RB Rapid Burning	25

If Vertical Openings are adequately protected (at least 1-hour fire rating): Area is the total of the largest floor (above ground level) plus 25% of the area of each of the next 2 immediately adjoining floors above that.

1) **Fire Flow** Building 1C
 Type of Construction:

nc

GF Area 2106 m²
 C =

0.8

 A* =

3159

 m²
 F =

9,892

 L/min

10,000

 L/min (round to the nearest 1,000L/min)

Note: Assuming Ordinary Construction building. Assuming Vertical Openings are adequately protected. Area is the total of the largest floor (level 1) plus 25% of the next 2 adjoining floors above.

2) **Occupancy Reduction/Surcharge**
 Contents Factor:

LC

 Reduction/Surcharge of

-15%

 =

-1,484

 L/min
 F = 10000L/min +

-1484

 L/min =

8,516

 L/min

3) **System Type Reduction**
 NFPA 13 Sprinkler:

YES	30%
-----	-----

 Standard Water Supply:

YES	10%
-----	-----

 Fully Supervised:

YES	10%
-----	-----

Total

50%

 Reduction of

50%

 L/min =

4,258

 L/min
 F = 8516L/min -

4,258

 L/min =

4,258

 L/min

4) **Separation Charge**

Building Face	Dist(m)	Charge
North	15	15%
East	25	10%
South	17	15%
West	20	15%
Total		55%

of 8516.2 L/min =

4,684

 L/min
 (max exposure charge can be 75%)

Separation	Charge	Separation	Charge
0 to 3m	25%	20.1 to 30 m	10%
3.1 to 10m	20%	30.1 to 45m	5%
10.1 to 20m	15%		

F = 4258L/min + 4684L/min =

8,942

 L/min (2,000L/min < F < 45,000L/min)

F =	9,000	L/min	(round to the nearest 1,000L/min)
F =	150	L/s	
F =	2,378	gpm	

Counterpoint Engineering Inc.

REQUIRED FIRE FLOW WORKSHEET - PROPOSED DEVELOPMENT

Fire Underwriters Survey

Project : Regent Park Phases 4&5
Project No: 21123

Guide for Determination of Required Flow Copyright I.S.O

$$F = 220C\sqrt{A}$$

where

- F = the required fire flow in litres per minute.
C = coefficient related to the type of construction.
= 1.5 for wood frame construction (structure essentially all combustible).
= 1.0 for ordinary construction (brick or other masonry walls, combustible floor and interior).
= 0.8 for non-combustible construction (unprotected metal structural components, masonry or metal walls).
= 0.6 for fire-resistive construction (fully protected frame, floors, roof).
A = The total floor area in square metres (including all storeys, but excluding basements at least 50 percent below grade) in the building being considered.

Type of Construction	Class Factor
WF Wood Frame	1.5
OC Ordinary Construction	1.0
NC Non-Combustible	0.8
FC Fire-Resistive	0.6

Area Notes for Fire Resistive Buildings (from FUS manual, 1999):

If Vertical Openings are inadequately protected (less than 1-hour fire rating): Area is the total of the two largest adjoining floors (above ground level) plus 50% of the area of each of the next 8 adjoining floors above that.

Contents	% Reduction
NC Non-Combustible	25
LC Limited Combustible	15
C Combustible	0
FB Free Burning	15
RB Rapid Burning	25

If Vertical Openings are adequately protected (at least 1-hour fire rating): Area is the total of the largest floor (above ground level) plus 25% of the area of each of the next 2 immediately adjoining floors above that.

1) Fire Flow

Type of Construction:

nc

Building 4L

GF Area 2015 m²

C=

0.8

A*=

3936 m²

F=

11,042 L/min

11,000 L/min

(round to the nearest 1,000L/min)

Note: Assuming Ordinary Construction building. Assuming Vertical Openings are adequately protected. Area is the total of the largest floor (level 1) plus 25% of the next 2 adjoining floors above.

2) Occupancy Reduction/Surcharge

Contents Factor:

LC

Reduction/Surcharge of

-15%

= -1,656 L/min

F=

11000L/min + -1656 L/min = 9,344 L/min

3) System Type Reduction

NFPA 13 Sprinkler:

YES 30%

Standard Water Supply:

YES 10%

Fully Supervised:

YES 10%

Total

50%

Reduction of

50% L/min

= 4,672 L/min

F=

9344L/min - 4,672 L/min = 4,672 L/min

4) Separation Charge

Building Face

Dist(m) Charge

North

15 15%

East

29 10%

South

27 10%

West

19 15%

Total

50%

of 9343.7 L/min = 4,672 L/min

(max exposure charge can be 75%)

Separation	Charge	Separation	Charge
0 to 3m	25%	20.1 to 30 m	10%
3.1 to 10m	20%	30.1 to 45m	5%
10.1 to 20m	15%		

F= 4672L/min + 4672L/min = 9,344 L/min (2,000L/min < F < 45,000L/min)

F=	9,000 L/min	(round to the nearest 1,000L/min)
F=	150 L/s	
F=	2,378 gpm	

Lozzi Aqua Check

Massimo Lozzi

12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Hydrant Flow Test Form

Job Location: Regent Park

Date: November 17, 2021

Time of Test: 9:00 am

Location of Flow Hydrant: At 463 Gerrard St. E


Residual Hydrant: S/W corner of River St. And Gerrard St. E

Main Size: 150mm

Static Pressure: 70 psi

	Number of Outlets & Orifice Size	Pitot Pressure (psi)	Flow (U.S. G.P.M.)	Residual Pressure (psi)
1.	Static	0	0	70
2.	1 x 2 ½	28	886	62
3.	2 x 2 ½	12	1160	60

Note: Flow test conducted in accordance with NFPA 291



Lozzi Aqua Check

Massimo Lozzi


12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Site Map:



counterpoint engineering

NFPA Theoretical Flow Calculations

Project Name: **Regent Park Phases 4&5**

Project Number: **21123**

Based on National Fire Protection Association Guidelines, the available flow at the minimum residual pressure of 20psi can be calculated based on the observed flow at the observed pressure readings, as follows:

River At Gerrard St. E.

$$Q_F = 29.83 \times c \times d^2 \times p^{0.5}, \text{ where}$$

Q_F = observed flow (US GPM)

c = hydrant nozzle coefficient (0.90 - 0.95)

d = nozzle diameter (in)

p = observed pitot pressure

$$Q_R = Q_F \times h_F^{0.54} / h_R^{0.54}, \text{ where}$$

Q_R = available flow

Q_F = observed flow (US GPM)

h_F = drop from measured static to desired baseline pressure

h_R = drop from measured static to measured residual pressure

Based on flow test results obtained by Lozzi Aqua Check, **November 17, 2021**

$c =$	0.9
$d =$	2.5 in
number of ports =	2
$p =$	12

$Q_F = 1163$ US GPM

Measured Static Pressure =	70 psi	
Measured Residual Pressure =	60 psi	
Desired Residual Pressure =	20 psi	, minimum per City of Toronto design criteria

$Q_R = 2772$ US GPM per fire connection
10,494 L/min

Lozzi Aqua Check

Massimo Lozzi

12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Hydrant Flow Test Form

Job Location: Regent Park

Date: November 17, 2021

Time of Test: 9:30 am

Location of Flow Hydrant: East side of River St., North of Oak St.


Residual Hydrant: S/E corner of Dundas St. E and River St.

Main Size: 150mm

Static Pressure: 75 psi

	Number of Outlets & Orifice Size	Pitot Pressure (psi)	Flow (U.S. G.P.M.)	Residual Pressure (psi)
1.	Static	0	0	75
2.	1 x 2 ½	60	1297	72
3.	2 x 2 ½	42	2170	70

Note: Flow test conducted in accordance with NFPA 291



Lozzi Aqua Check

Massimo Lozzi


12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Site Map:



counterpoint engineering

NFPA Theoretical Flow Calculations

Project Name: **Regent Park Phases 4&5**

Project Number: **21123**

Based on National Fire Protection Association Guidelines, the available flow at the minimum residual pressure of 20psi can be calculated based on the observed flow at the observed pressure readings, as follows:

River At Oak

$$Q_F = 29.83 \times c \times d^2 \times p^{0.5}, \text{ where}$$

Q_F = observed flow (US GPM)

c = hydrant nozzle coefficient (0.90 - 0.95)

d = nozzle diameter (in)

p = observed pitot pressure

$$Q_R = Q_F \times h_F^{0.54} / h_R^{0.54}, \text{ where}$$

Q_R = available flow

Q_F = observed flow (US GPM)

h_F = drop from measured static to desired baseline pressure

h_R = drop from measured static to measured residual pressure

Based on flow test results obtained by Lozzi Aqua Check, **November 17, 2021**

$c =$	0.9
$d =$	2.5 in
number of ports =	2
$p =$	42

$Q_F =$ **2175 US GPM**

Measured Static Pressure =	75 psi
Measured Residual Pressure =	70 psi
Desired Residual Pressure =	20 psi

, minimum per City of Toronto design criteria

$Q_R =$ **7939 US GPM** per fire connection
30,054 L/min

Lozzi Aqua Check

Massimo Lozzi

12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Hydrant Flow Test Form

Job Location: Regent Park

Date: November 17, 2021

Time of Test: 10:00 am

Location of Flow Hydrant: On Oak St. near Sackville St.


Residual Hydrant: On Oak St. Near Sumach St.

Main Size: 200mm

Static Pressure: 72 psi

	Number of Outlets & Orifice Size	Pitot Pressure (psi)	Flow (U.S. G.P.M.)	Residual Pressure (psi)
1.	Static	0	0	72
2.	1 x 2 ½	12	580	70
3.	2 x 2 ½	8	947	68

Note: Flow test conducted in accordance with NFPA 291



Lozzi Aqua Check

Massimo Lozzi


12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Site Map:



counterpoint engineering

NFPA Theoretical Flow Calculations

Project Name: **Regent Park Phases 4&5**

Project Number: **21123**

Based on National Fire Protection Association Guidelines, the available flow at the minimum residual pressure of 20psi can be calculated based on the observed flow at the observed pressure readings, as follows:

Oak At Sackville

$$Q_F = 29.83 \times c \times d^2 \times p^{0.5}, \text{ where}$$

Q_F = observed flow (US GPM)

c = hydrant nozzle coefficient (0.90 - 0.95)

d = nozzle diameter (in)

p = observed pitot pressure

$$Q_R = Q_F \times h_F^{0.54} / h_R^{0.54}, \text{ where}$$

Q_R = available flow

Q_F = observed flow (US GPM)

h_F = drop from measured static to desired baseline pressure

h_R = drop from measured static to measured residual pressure

Based on flow test results obtained by Lozzi Aqua Check, **November 17, 2021**

c = 0.9
 d = 2.5 in
number of ports = 2
 p = 8

Q_F = **949 US GPM**

Measured Static Pressure = 72 psi
Measured Residual Pressure = 68 psi
Desired Residual Pressure = 20 psi, minimum per City of Toronto design criteria

Q_R = **3792 US GPM** per fire connection
14,355 L/min

Lozzi Aqua Check

Massimo Lozzi

12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Hydrant Flow Test Form

Job Location: Regent Park

Date: November 17, 2021

Time of Test: 10:30 am

Location of Flow Hydrant: 407 Gerrard St. E


Residual Hydrant: S/W corner of Gerrard St. E & Sumach St.

Main Size: 150mm

Static Pressure: 54 psi

	Number of Outlets & Orifice Size	Pitot Pressure (psi)	Flow (U.S. G.P.M.)	Residual Pressure (psi)
1.	Static	0	0	54
2.	1 x 2 ½	28	886	50
3.	2 x 2 ½	12	1160	48

Note: Flow test conducted in accordance with NFPA 291



Lozzi Aqua Check

Massimo Lozzi


12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Site Map:



Lozzi Aqua Check

Massimo Lozzi

12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Hydrant Flow Test Form

Job Location: Regent Park

Date: November 17, 2021

Time of Test: 11:00 am

Location of Flow Hydrant: On Dreamers Way North of Oak St.


Residual Hydrant: On Dreamers Way South of Gerrard St. E.

Main Size: 200mm

Static Pressure: 65 psi

	Number of Outlets & Orifice Size	Pitot Pressure (psi)	Flow (U.S. G.P.M.)	Residual Pressure (psi)
1.	Static	0	0	65
2.	1 x 2 ½	54	1230	60
3.	2 x 2 ½	32	1894	52

Note: Flow test conducted in accordance with NFPA 291



counterpoint engineering

NFPA Theoretical Flow Calculations

Project Name: **Regent Park Phases 4&5**

Project Number: **21123**

Based on National Fire Protection Association Guidelines, the available flow at the minimum residual pressure of 20psi can be calculated based on the observed flow at the observed pressure readings, as follows:

Dreamer Way at Gerrard st. E.

$$Q_F = 29.83 \times c \times d^2 \times p^{0.5}, \text{ where}$$

Q_F = observed flow (US GPM)

c = hydrant nozzle coefficient (0.90 - 0.95)

d = nozzle diameter (in)

p = observed pitot pressure

$$Q_R = Q_F \times h_F^{0.54} / h_R^{0.54}, \text{ where}$$

Q_R = available flow

Q_F = observed flow (US GPM)

h_F = drop from measured static to desired baseline pressure

h_R = drop from measured static to measured residual pressure

Based on flow test results obtained by Lozzi Aqua Check, **November 17, 2021**

$c =$ 0.9
 $d =$ 2.5 in
number of ports = 2
 $p =$ 32

$Q_F =$ **1898 US GPM**

Measured Static Pressure = 65 psi
Measured Residual Pressure = 52 psi
Desired Residual Pressure = 20 psi, minimum per City of Toronto design criteria

$Q_R =$ **3712 US GPM** per fire connection
14,051 L/min

Lozzi Aqua Check

Massimo Lozzi

12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Hydrant Flow Test Form

Job Location: Regent Park

Date: November 17, 2021

Time of Test: 9:00 am

Location of Flow Hydrant: At 463 Gerrard St. E


Residual Hydrant: S/W corner of River St. And Gerrard St. E

Main Size: 150mm

Static Pressure: 70 psi

	Number of Outlets & Orifice Size	Pitot Pressure (psi)	Flow (U.S. G.P.M.)	Residual Pressure (psi)
1.	Static	0	0	70
2.	1 x 2 ½	28	886	62
3.	2 x 2 ½	12	1160	60

Note: Flow test conducted in accordance with NFPA 291



Lozzi Aqua Check

Massimo Lozzi


12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Site Map:



Lozzi Aqua Check

Massimo Lozzi

12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Hydrant Flow Test Form

Job Location: Regent Park

Date: November 17, 2021

Time of Test: 9:30 am

Location of Flow Hydrant: East side of River St., North of Oak St.


Residual Hydrant: S/E corner of Dundas St. E and River St.

Main Size: 150mm

Static Pressure: 75 psi

	Number of Outlets & Orifice Size	Pitot Pressure (psi)	Flow (U.S. G.P.M.)	Residual Pressure (psi)
1.	Static	0	0	75
2.	1 x 2 ½	60	1297	72
3.	2 x 2 ½	42	2170	70

Note: Flow test conducted in accordance with NFPA 291



Lozzi Aqua Check

Massimo Lozzi


12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Site Map:



Lozzi Aqua Check

Massimo Lozzi

12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Hydrant Flow Test Form

Job Location: Regent Park

Date: November 17, 2021

Time of Test: 10:00 am

Location of Flow Hydrant: On Oak St. near Sackville St.


Residual Hydrant: On Oak St. Near Sumach St.

Main Size: 200mm

Static Pressure: 72 psi

	Number of Outlets & Orifice Size	Pitot Pressure (psi)	Flow (U.S. G.P.M.)	Residual Pressure (psi)
1.	Static	0	0	72
2.	1 x 2 ½	12	580	70
3.	2 x 2 ½	8	947	68

Note: Flow test conducted in accordance with NFPA 291



Lozzi Aqua Check

Massimo Lozzi


12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Site Map:



Lozzi Aqua Check

Massimo Lozzi

12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Hydrant Flow Test Form

Job Location: Regent Park

Date: November 17, 2021

Time of Test: 10:30 am

Location of Flow Hydrant: 407 Gerrard St. E


Residual Hydrant: S/W corner of Gerrard St. E & Sumach St.

Main Size: 150mm

Static Pressure: 54 psi

	Number of Outlets & Orifice Size	Pitot Pressure (psi)	Flow (U.S. G.P.M.)	Residual Pressure (psi)
1.	Static	0	0	54
2.	1 x 2 ½	28	886	50
3.	2 x 2 ½	12	1160	48

Note: Flow test conducted in accordance with NFPA 291



Lozzi Aqua Check

Massimo Lozzi


12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Site Map:



Lozzi Aqua Check

Massimo Lozzi

12307 Woodbine Ave, P.O. Box 519

Cell: 416 990-2131

Gormley, ON L0H 1G0

E-mail: lozziaquacheck@gmail.com

Hydrant Flow Test Form

Job Location: Regent Park

Date: November 17, 2021

Time of Test: 11:00 am

Location of Flow Hydrant: On Dreamers Way North of Oak St.


Residual Hydrant: On Dreamers Way South of Gerrard St. E.

Main Size: 200mm

Static Pressure: 65 psi

	Number of Outlets & Orifice Size	Pitot Pressure (psi)	Flow (U.S. G.P.M.)	Residual Pressure (psi)
1.	Static	0	0	65
2.	1 x 2 ½	54	1230	60
3.	2 x 2 ½	32	1894	52

Note: Flow test conducted in accordance with NFPA 291



Lozzi Aqua Check

12307 Woodbine Ave, P.O. Box 519

Gormley, ON L0H 1G0

Site Map:

Map not available.

Massimo Lozzi

Cell: 416 990-2131


E-mail: lozziaquacheck@gmail.com



Appendix D

Proposed Public Roads

TUBMAN EXTENSION





Appendix E

Groundwater

SERVICING REPORT GROUNDWATER SUMMARY

The form is to be completed by the Professional that prepared the Servicing Report.
 Use of the form by the City of Toronto is not to be construed as verification of engineering/hydrological content.

For City Staff Use Only:	
Name of ECS Case Manager (please print)	

A. SITE INFORMATION		Included in SR (reference page number)	Report Includes this information City staff (Check)
Date Servicing Report was prepared: April 10, 2023		Cover	
Title of Servicing Report: FUNCTIONAL SERVICING & STORMWATER MANAGEMENT REPORT		Cover	
Name of Consulting Firm that prepared Servicing Report: Counterpoint Engineering		Cover	
Site Address	Regent Park Toronto, Ontario	Cover	
Postal Code			
Property Owner (identified on planning request for comments memo)	Toronto Community Housing Corp. & 2747199 Ontario Limited (Tridel)	Cover	
Proposed description of the project (ex. number of point towers, number of podiums, etc.)	Four blocks of multiple towers up to 39 storey	Page 4	
Land Use (ex. commercial, residential, mixed, industrial, institutional) as defined by the Planning Act	Mixed Use	Page 4	
Number of below grade levels	2		

SERVICING REPORT GROUNDWATER SUMMARY

<p>Does the SR include a private water drainage system (PWDS)?</p> <p>PWDS: Private Water Drainage System: A subsurface drainage system which may consist of but is not limited to weeping tile(s), foundation drain(s), private water collection sump(s), private water pump or any combination thereof for the disposal of private water on the surface of the ground or to a private sewer connection or drainage system for disposal in a municipal sewer.</p>	<p>If Yes continue completing Section B (Information Relating to Groundwater) <u>ONLY</u></p> <p>If Yes, Number of PWDS? <u> 0 </u></p> <p><i>(Each of these PWDS may require a separate Toronto Water agreement)</i></p> <p>If No skip to Sections C (On-site Groundwater Containment) and/or D (Water Tight Requirements) as applicable</p>	<p><input type="radio"/> YES</p> <p><input checked="" type="radio"/> NO</p>	
B. INFORMATION RELATING TO GROUNDWATER		Included in SR (reference page number)	Report Includes this information City Staff (Check)
<p>A copy of the pump schedule(s) for ALL groundwater sump pump(s) for the development site has been included in the SR</p> <p style="text-align: center;"><u>or</u></p> <p>A letter written by a Mechanical Consultant (signed and stamped by a Professional Engineer of Ontario) shall be attached to the SR stating the peak flow rate of the groundwater discharge for the development site for all groundwater sump pump(s). This peak flow rate must be based on the pump schedule(s) that have been designed by the</p>			

SERVICING REPORT GROUNDWATER SUMMARY

<p>Mechanical Consultant. A template of this letter is attached in Schedule A.</p> <p>**If there is more than one groundwater sump they must ALL be included in the letters along with a combined flow**</p>			
<p>Is it proposed that the groundwater from the development site will be discharged to the sanitary, combined or storm sewer?</p>	<p><input checked="" type="radio"/> Sanitary Sewer</p> <p><input type="radio"/> Combined Sewer</p> <p><input type="radio"/> Storm Sewer</p>		
<p>Will the proposed PWDS discharge from the site go to the Western Beaches Tunnel (WBT)?</p> <p>*Reference attached WBT drainage map*</p>	<p><input type="radio"/> YES <input checked="" type="radio"/> NO</p> <p>If Yes, private water discharge fees will apply and site requires a sanitary discharge agreement.</p>		
<p>What is the street name where the receiving sewer is located?</p>	<p>Dreamers Way, Oak Street, Tubman.</p>		
<p>What is the diameter of the receiving sewer?</p>	<p>250 & 300</p>		
<p>Is there capacity in the proposed local sewer system?</p> <p><input checked="" type="radio"/> YES <input type="radio"/> NO</p>	<p>Are there any improvements required to the sewer system? If yes, identify them below and refer to the section and page number of the SR where this information can be found.</p> <p>If a sewer upgrade is required, the owner is required to enter into an Agreement with the City to improve the infrastructure?</p> <p><input type="radio"/> YES</p>		
<p>Has Toronto Water-WIM confirmed that there is there capacity in the proposed infrastructure listed below?</p> <p>- Trunk System?</p> <p><input type="radio"/> YES <input type="radio"/> NO</p>			

SERVICING REPORT GROUNDWATER SUMMARY

<p>-Pumping Station? <input type="radio"/> YES <input type="radio"/> NO</p> <p>-Wastewater treatment plant? <input type="radio"/> YES <input type="radio"/> NO</p> <p>-Outfall? <input type="radio"/> YES <input type="radio"/> NO</p> <p>-Combined Sewer Overflow? <input type="radio"/> YES <input type="radio"/> NO</p> <p>*If there is no capacity in any of the above then alternative options need to be considered by the Owner and site cannot discharge to City sewer system.</p>			
<p>Total allowable peak flow rate during a 100 year storm event (L/sec) to storm sewer</p> <p>When groundwater is to be discharged to the storm sewer the total groundwater and stormwater discharge shall not exceed the permissible peak flow rate during a 2 year pre development storm event, as per the City's Wet Weather Flow Management Guidelines, dated 2006</p>	<p><u>790.1</u> L/sec</p>	<p>Page 6</p>	
<p>Short-Term Groundwater Discharge Provide proposed total flow rate to the sanitary/combined sewer in post-development scenario</p> <p>Total Flow (L/sec) = sanitary flow + peak short-term groundwater flow rate</p>	<p>To be Determined during the SPA process for each block</p> <p><u>N/A</u> L/sec</p>		

SERVICING REPORT GROUNDWATER SUMMARY

<p>Long-Term Groundwater Discharge Provide proposed total flow rate to the sanitary/combined sewer in post-development scenario</p> <p>Total Flow (L/sec) = sanitary flow + peak long-term groundwater flow rate</p>	<p style="text-align: center;"><u>0</u> L/sec</p>	<p>Page 9</p>	
<p>Does the water quality meet the receiving sewer Bylaw limits?</p> <p><input type="radio"/> YES</p> <p><input checked="" type="radio"/> NO</p>	<p>If the water quality does not meet the applicable receiving sewer Bylaw limits and the applicant is proposing a treatment system the applicant will need to include a letter stating that a treatment system will be installed and the details of the treatment system will be included in the private water discharge application that will be submitted to TW EM&P.</p>		
<p>C. ON-SITE GROUNDWATER CONTAINMENT</p>		<p>Included in SR (reference page number)</p>	<p>Report Includes this information City Staff (Check)</p>
<p>How is the site proposing to manage the groundwater discharge on site?</p>	<p>Watertight Foundation</p>	<p>Page 9</p>	
<p>Has the above proposal been approved by:</p>	<p><input type="radio"/> TW-WIM</p> <p>And</p> <p><input type="radio"/> TW-EM&P</p> <p>And</p> <p><input type="radio"/> ECS</p>		

SERVICING REPORT GROUNDWATER SUMMARY

<p>If the site is proposing a groundwater infiltration gallery, has it been stated that the groundwater infiltration gallery will not be connected to the municipal sewer? A connection between the infiltration gallery/dry well and the municipal sewer is not permitted</p> <p>Please be advised if an infiltration gallery/dry well on site is not connected to the municipal sewer, the site must submit two letters using the templates in Schedule B and Schedule C.</p>	<p><input type="radio"/> YES</p> <p><input checked="" type="radio"/> NO</p>		
<p>Confirm that the infiltration gallery can infiltrate 100% of the expected peak groundwater flow year round, ensure that the top of the infiltration trench is below the frost line (1.8m depth), not less than 5 m from the building foundation, bottom of the trench 1m above the seasonally high water table, and located so that the drainage is away from the building.</p>			
<p align="center">D. WATER TIGHT REQUIREMENTS</p>		<p align="center">Included in SR (reference page number)</p>	<p align="center">Report Includes this information City Staff (Check)</p>
<p>If the site is proposing a water tight structure:</p> <ol style="list-style-type: none"> 1. The owner must submit a letter using the template in Schedule D. 2. A Professional Engineer (Structural), licensed to practice in Ontario and qualified in the subject must submit a letter using the template in Schedule E. 3. A Professional Engineer (Mechanical), licensed to practice in Ontario and qualified in the subject must submit a letter using the template in Schedule F. 			

December 2017

SERVICING REPORT GROUNDWATER SUMMARY

Provide a copy of the approved SR to Toronto Water Environmental Monitoring & Protection Unit at pwapplication@toronto.ca.

Consulting Firm that prepared Servicing Report: Counterpoint Engineering

Professional Engineer who completed the report summary: Rasheed Serrao
Print Name

Professional Engineer who completed the report summary: _____
Signature

